



Bid Number/बोली क्रमांक (बिड संख्या):  
GEM/2024/B/5033695  
Dated/दिनांक : 11-06-2024

### Bid Document/ बिड दस्तावेज़

Bid Details/बिड विवरण	
Bid End Date/Time/बिड बंद होने की तारीख/समय	02-07-2024 17:00:00
Bid Opening Date/Time/बिड खुलने की तारीख/समय	02-07-2024 17:30:00
Bid Offer Validity (From End Date)/बिड पेशकश वैधता (बंद होने की तारीख से)	120 (Days)
Ministry/State Name/मंत्रालय/राज्य का नाम	Ministry Of Ports, Shipping And Waterways
Department Name/विभाग का नाम	Na
Organisation Name/संगठन का नाम	Kandla Port Trust
Office Name/कार्यालय का नाम	Deendayal Port Trust, Post Box No. 50, Administrative Building, Gandhidham, Kutch, Gujarat 370201
Total Quantity/कुल मात्रा	17000
Item Category/मद केटेगरी	XLPE Cable for Working Voltages up to and Including 1.1 KV as per IS 7098 (Part 1) (Q2)
Minimum Average Annual Turnover of the bidder (For 3 Years)/बिडर का न्यूनतम औसत वार्षिक टर्नओवर (3 वर्षों का)	21 Lakh (s)
Years of Past Experience Required for same/similar service/उन्हीं/समान सेवाओं के लिए अपेक्षित विगत अनुभव के वर्ष	3 Year (s)
MSE Exemption for Years of Experience and Turnover/ अनुभव के वर्षों से एमएसई छूट	No
Startup Exemption for Years of Experience and Turnover/ अनुभव के वर्षों से स्टार्टअप छूट	No
Document required from seller/विक्रेता से मांगे गए दस्तावेज़	Experience Criteria,Past Performance,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate,Additional Doc 1 (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Past Performance/विगत प्रदर्शन	80 %
Bid to RA enabled/बिड से रिवर्स नीलामी सक्रिय किया	No
Type of Bid/बिड का प्रकार	Two Packet Bid

**Bid Details/बिड विवरण**

<b>Primary product category</b>	XLPE Cable for Working Voltages up to and Including 1.1 KV as per IS 7098 (Part 1)
<b>Time allowed for Technical Clarifications during technical evaluation/तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय</b>	5 Days
<b>Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)</b>	No
<b>Evaluation Method/मूल्यांकन पद्धति</b>	Total value wise evaluation

**EMD Detail/ईएमडी विवरण**

Advisory Bank/एडवाइजरी बैंक	Bank of India
EMD Amount/ईएमडी राशि	70000

**ePBG Detail/ईपीबीजी विवरण**

Advisory Bank/एडवाइजरी बैंक	Bank of India
ePBG Percentage(%) / ईपीबीजी प्रतिशत (%)	5.00
Duration of ePBG required (Months) / ईपीबीजी की अपेक्षित अवधि (महीने).	14

(a). EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy./जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित कैटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज प्रस्तुत करने हैं। एमएसई कैटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।

(b). EMD & Performance security should be in favour of Beneficiary, wherever it is applicable./ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए।

**Beneficiary/लाभार्थी :**

Deendayal Port Authority  
Deendayal Port Authority, Office of Chief Operations Manager Administrative Office building, Off Shore Oil Terminal, Vadinar - 361010  
(Deendayal Port Authority)

**Splitting/विभाजन**

Bid splitting not applied/बोली विभाजन लागू नहीं किया गया.

**MII Purchase Preference/एमआईआई खरीद वरीयता**

MII Purchase Preference/एमआईआई खरीद वरीयता
--

Yes
-----

### **MSE Purchase Preference/एमएसई खरीद वरीयता**

MSE Purchase Preference/एमएसई खरीद वरीयता
---

Yes
-----

1. The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated above in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3-year-old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

2. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

3. Preference to Make In India products (For bids < 200 Crore): Preference shall be given to Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a Class 1 local supplier is denoted in the bid document. If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020. Only Class-I and Class-II Local suppliers as per MII order dated 4.6.2020 will be eligible to bid. Non - Local suppliers as per MII order dated 04.06.2020 are not eligible to participate. However, eligible micro and small enterprises will be allowed to participate .The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023.

[OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017.

4. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 25% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

5. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 80% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

## XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) ( 7000 meter )

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

### Technical Specifications/तकनीकी विशिष्टियाँ

\* As per GeM Category Specification/जेम कैटेगरी विशिष्टि के अनुसार

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	<b>Conformity of the specification for XLPE cable</b>	as per IS:7098 (Part 1): 1988 latest
	<b>Cables suitable for use in mines</b>	No
	<b>Cables suitable for use in low temperature applications</b>	No
GENERIC	<b>Classification of cables for improved fire performance category</b>	01
	<b>Nominal Area of Conductor (in Sq mm)</b>	16
	<b>Number of core (in Nos)</b>	4
CONSTRUCTION	<b>Material of conductor</b>	Aluminium
	Conductor material standard	as per IS:8130:2013 latest
	Construction of the conductor	Stranded and shaped
	<b>Type of inner sheath</b>	Thermoplastic
ARMOURING	<b>Type of cable</b>	Armoured cable
	<b>Material of armouring</b>	Galvanized round steel wire, Galvanized steel formed wire
	<b>Type of armouring</b>	Single wire, Single strip
OUTER SHEATH	Outer sheath standard	Conforming to IS:5831:1984 latest
	Type of outer sheath	PVC-ST2
	Colour of outer sheath	Black
MARKING ON CABLE	Manufacturer's identification on cable	as per Cl.17.1 of IS:7098 Part 1: latest
	Type of sequential marking on cable	Screen printing on cable, Embossed on cable
	Cable identification	as per Cl.17.2 of IS:7098 Part 1: latest
PACKING AND MARKING	Packing and marking	as per Cl.18.1 and 18.2 of IS:7098 Part 1: latest
	Cable wound on	ISI Marked Wooden drum

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Drum standard	as per IS:10418 latest
	Standard length of cable on drum (in m)	500
	Marking on the drum	as per Cl.18.2 of IS:7098 Part 1: latest
CERTIFICATION	Availability of type test report from Govt Lab/ NABL accredited LAB / ILAC accredited LAB	Yes as per Cl.15 of IS:7098 Part 1
	<b>Availability of Optional Test Reports</b>	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

**Additional Specification Parameters - XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) ( 7000 meter )**

Specification Parameter Name	Bid Requirement (Allowed Values)
Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour & Type Test Certificate

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	A.Ramasamy	361010,OFF-SHORE OIL TERMINAL (OOT) AO BUILDING VADINAAR DIST: DEVBHOOMI DWARKA	7000	45

**XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) ( 5000 meter )**

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

**Technical Specifications/तकनीकी विशिष्टियाँ**

[\\* As per GeM Category Specification/जेम कैटेगरी विशिष्टि के अनुसार](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	<b>Conformity of the specification for XLPE cable</b>	as per IS:7098 (Part 1): 1988 latest
	<b>Cables suitable for use in mines</b>	No
	<b>Cables suitable for use in low temperature applications</b>	No
GENERIC	<b>Classification of cables for improved fire performance category</b>	01
	<b>Nominal Area of Conductor (in Sq mm)</b>	35
	<b>Number of core (in Nos)</b>	3.5
CONSTRUCTION	<b>Material of conductor</b>	Aluminium
	Conductor material standard	as per IS:8130:2013 latest
	Construction of the conductor	Stranded and shaped
	<b>Type of inner sheath</b>	Thermoplastic
ARMOURING	<b>Type of cable</b>	Armoured cable
	<b>Material of armouring</b>	Galvanized steel formed wire
	<b>Type of armouring</b>	Single wire, Single strip
OUTER SHEATH	Outer sheath standard	Conforming to IS:5831:1984 latest
	Type of outer sheath	PVC-ST2
MARKING ON CABLE	Manufacturer's identification on cable	as per Cl.17.1 of IS:7098 Part 1: latest
	Type of sequential marking on cable	Screen printing on cable, Embossed on cable
PACKING AND MARKING	Cable wound on	ISI Marked Wooden drum
	Drum standard	as per IS:10418 latest
	Standard length of cable on drum (in m)	500
	Marking on the drum	as per Cl.18.2 of IS:7098 Part 1: latest
CERTIFICATION	Availability of type test report from Govt Lab/ NABL accredited LAB / ILAC accredited LAB	Yes as per Cl.15 of IS:7098 Part 1
	<b>Availability of Optional Test Reports</b>	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

**Additional Specification Parameters - XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) ( 5000 meter )**

Specification Parameter Name	Bid Requirement (Allowed Values)
Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour & Type Test Certificate

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	A.Ramasamy	361010,OFF-SHORE OIL TERMINAL (OOT) AO BUILDING VADINAAR DIST: DEVBHOOMI DWARKA	5000	45

**XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) ( 500 meter )**

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

**Technical Specifications/तकनीकी विशिष्टियाँ**

\* As per GeM Category Specification/जेम केटेगरी विशिष्टि के अनुसार

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	No
	Cables suitable for use in low temperature applications	No
GENERIC	Classification of cables for improved fire performance category	01
	Nominal Area of Conductor (in Sq mm)	70
	Number of core (in Nos)	3.5
CONSTRUCTION	Material of conductor	Aluminium

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Conductor material standard	as per IS:8130:2013 latest
	Construction of the conductor	Stranded and shaped
	<b>Type of inner sheath</b>	Thermoplastic
ARMOURING	<b>Type of cable</b>	Armoured cable
	<b>Material of armouring</b>	Galvanized round steel wire, Galvanized steel formed wire
	<b>Type of armouring</b>	Single wire, Single strip
OUTER SHEATH	Outer sheath standard	Conforming to IS:5831:1984 latest
	Type of outer sheath	PVC-ST2
MARKING ON CABLE	Manufacturer's identification on cable	as per Cl.17.1 of IS:7098 Part 1: latest
	Type of sequential marking on cable	Screen printing on cable, Embossed on cable
	Cable identification	as per Cl.17.2 of IS:7098 Part 1: latest
PACKING AND MARKING	Packing and marking	as per Cl.18.1 and 18.2 of IS:7098 Part 1: latest
	Cable wound on	ISI Marked Wooden drum
	Drum standard	as per IS:10418 latest
	Standard length of cable on drum (in m)	500
	Marking on the drum	as per Cl.18.2 of IS:7098 Part 1: latest
CERTIFICATION	Availability of type test report from Govt Lab/ NABL accredited LAB / ILAC accredited LAB	Yes as per Cl.15 of IS:7098 Part 1
	<b>Availability of Optional Test Reports</b>	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

**Additional Specification Parameters - XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) ( 500 meter )**

Specification Parameter Name	Bid Requirement (Allowed Values)
Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour & Type Test Certificate

\* Bidders offering must also comply with the additional specification parameters mentioned above.



**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्र**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्र	Delivery Days/डिलीवरी के दिन
1	A.Ramasamy	361010,OFF-SHORE OIL TERMINAL (OOT) AO BUILDING VADINAAR DIST: DEVBHOOMI DWARKA	500	45

**XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) ( 3000 meter )**

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Bis Required	Yes
--------------	-----

**Technical Specifications/तकनीकी विशिष्टियाँ**

\* As per GeM Category Specification/जेम केटेगरी विशिष्टि के अनुसार

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	<b>Conformity of the specification for XLPE cable</b>	as per IS:7098 (Part 1): 1988 latest
	<b>Cables suitable for use in mines</b>	No
	<b>Cables suitable for use in low temperature applications</b>	No
GENERIC	<b>Classification of cables for improved fire performance category</b>	01
	<b>Nominal Area of Conductor (in Sq mm)</b>	120
	<b>Number of core (in Nos)</b>	3.5
CONSTRUCTION	<b>Material of conductor</b>	Aluminium
	Conductor material standard	as per IS:8130:2013 latest
	Construction of the conductor	Stranded and shaped
	<b>Type of inner sheath</b>	Thermoplastic
ARMOURING	<b>Type of cable</b>	Armoured cable
	<b>Material of armouring</b>	Galvanized round steel wire, Galvanized steel formed wire
	<b>Type of armouring</b>	Single wire, Single strip
OUTER SHEATH	Outer sheath standard	Conforming to IS:5831:1984 latest

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Type of outer sheath	PVC-ST2
	Colour of outer sheath	Black
MARKING ON CABLE	Manufacturer's identification on cable	as per Cl.17.1 of IS:7098 Part 1: latest
	Type of sequential marking on cable	Screen printing on cable, Embossed on cable
	Cable identification	as per Cl.17.2 of IS:7098 Part 1: latest
PACKING AND MARKING	Packing and marking	as per Cl.18.1 and 18.2 of IS:7098 Part 1: latest
	Cable wound on	ISI Marked Wooden drum
	Drum standard	as per IS:10418 latest
	Standard length of cable on drum (in m)	500
	Marking on the drum	as per Cl.18.2 of IS:7098 Part 1: latest
CERTIFICATION	Availability of type test report from Govt Lab/ NABL accredited LAB / ILAC accredited LAB	Yes as per Cl.15 of IS:7098 Part 1
	<b>Availability of Optional Test Reports</b>	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

**Additional Specification Parameters - XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) ( 3000 meter )**

Specification Parameter Name	Bid Requirement (Allowed Values)
Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour & Type Test Certificate

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	A.Ramasamy	361010,OFF-SHORE OIL TERMINAL (OOT) AO BUILDING VADINAAR DIST: DEVBHOOMI DWARKA	3000	45

### XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) ( 1500 meter )

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Bis Required	Yes
--------------	-----

### Technical Specifications/तकनीकी विशिष्टियाँ

\* As per GeM Category Specification/जेम केटेगरी विशिष्टि के अनुसार

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	No
	Cables suitable for use in low temperature applications	No
GENERIC	Classification of cables for improved fire performance category	01
	Nominal Area of Conductor (in Sq mm)	240
	Number of core (in Nos)	3.5
CONSTRUCTION	Material of conductor	Aluminium
	Conductor material standard	as per IS:8130:2013 latest
	Construction of the conductor	Stranded and shaped
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized round steel wire, Galvanized steel formed wire
	Type of armouring	Single wire, Single strip
OUTER SHEATH	Outer sheath standard	Conforming to IS:5831:1984 latest
	Type of outer sheath	PVC-ST2

Specification	Specification Name/विशिष्ट का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Colour of outer sheath	Black
MARKING ON CABLE	Manufacturer's identification on cable	as per Cl.17.1 of IS:7098 Part 1: latest
	Type of sequential marking on cable	Screen printing on cable, Embossed on cable
	Cable identification	as per Cl.17.2 of IS:7098 Part 1: latest
PACKING AND MARKING	Packing and marking	as per Cl.18.1 and 18.2 of IS:7098 Part 1: latest
	Cable wound on	ISI Marked Wooden drum
	Drum standard	as per IS:10418 latest
	Standard length of cable on drum (in m)	500
	Marking on the drum	as per Cl.18.2 of IS:7098 Part 1: latest
CERTIFICATION	Availability of type test report from Govt Lab/ NABL accredited LAB / ILAC accredited LAB	Yes as per Cl.15 of IS:7098 Part 1
	<b>Availability of Optional Test Reports</b>	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

**Additional Specification Parameters - XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) ( 1500 meter )**

Specification Parameter Name	Bid Requirement (Allowed Values)
Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour & Type Test Certificate

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	A.Ramasamy	361010,OFF-SHORE OIL TERMINAL (OOT) AO BUILDING VADINAAR DIST: DEVBHOOMI DWARKA	1500	45

## **Buyer Added Bid Specific Terms and Conditions/क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें**

### **1. Generic**

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity by up to 25% of the contracted quantity during the currency of the contract at the contracted rates. Bidders are bound to accept the orders accordingly.

### **2. Buyer Added Bid Specific ATC**

Buyer uploaded ATC document [Click here to view the file.](#)

## **Disclaimer/अस्वीकरण**

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

[This Bid is also governed by the General Terms and Conditions/ यह बिड सामान्य शर्तों के अंतर्गत भी शासित है](#)

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws./जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो।बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।

**---Thank You/धन्यवाद---**