

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof inside cargo jetty area.

DEENDAYAL PORT AUTHORITY

ISO 9001:2008 | ISO 14001 | ISPS COMPLIANT PORT



MECHANICAL ENGINEERING DEPARTMENT

ELECTRICAL DIVISION

TENDER NO. EL/WK/2830

“Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof inside cargo jetty area.”

Executive Engineer (E)
Electrical Division
Deendayal Port Authority,
Ground Floor,
Port & Custom Building,
New Kandla – 370 210.
Phone No. (02836) 220636/270184
Fax No. (02836) 270184/270475
Email:-see@deendayalport.gov.in

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof inside cargo jetty area.

CONTENTS OF TENDER DOCUMENT

Bid Reference No. EL/WK/2830

- **NIT** : **Invitation for Bids**

- **SECTION I** : **Instruction to Bidders**

- **SECTION II** : **General Conditions of Contract**

- **SECTION III** : **Special Conditions of Contract**

- **SECTION IV** : **Forms of Bid**

- **SECTION V** : **Scope of Work & Technical Specifications**

- **SECTION VI** : **Bill of Quantities**

- **Section VII** : **Evidence Towards Site Visit**

- **Section VIII** : **Approved Make List for Electrical Items**

- **Section IX** : **Integrity pact**

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof inside cargo jetty area.

DEENDAYAL PORT AUTHORITY

TENDER NOTICE NO.EL/WK/2830

Name of work	"Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof inside cargo jetty area."																									
Estimated cost put to tender	₹ 53,71,908/-																									
Tender fee :	<p>Rs. 1000 + (GST) Present rate of GST is 18% Through on line transfer in PNB bank account no. 2177002100004628 - Deendayal Port Authority - (IFSC code PUNB0217700). Scanned copy of RTGS no. and date of transfer may be uploaded on (n) procure website. In case of Micro and Small Enterprise (MSEs) holding valid certificate issued by any agencies/organization under The Ministry of Micro, Small and Medium Enterprises indicating the list of activity related to the subject tender as per National Industrial Classification-2008 mentioned in the table below only shall become eligible for exemption from payment of Tender fee/EMD. Such bidder shall upload the scanned copy of valid certificate along with Bid Securing Declaration Form (Form 7 in Section IV) in preliminary bid.</p> <table border="1"> <thead> <tr> <th>Level</th> <th>Description</th> </tr> </thead> <tbody> <tr> <td>Section - F</td> <td>CONSTRUCTION</td> </tr> <tr> <td>Division - 43</td> <td>Specialized construction activities</td> </tr> <tr> <td>Group - 432</td> <td>Electrical, plumbing and other construction installation activities</td> </tr> <tr> <td>Class - 4321</td> <td>Electrical installation</td> </tr> <tr> <td>Sub Class - 43219</td> <td>Other electrical installation n.e.c.</td> </tr> </tbody> </table> <p>OR</p> <table border="1"> <thead> <tr> <th>Level</th> <th>Description</th> </tr> </thead> <tbody> <tr> <td>Section - D</td> <td>ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY</td> </tr> <tr> <td>Division - 35</td> <td>ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY</td> </tr> <tr> <td>Group - 351</td> <td>Electric power generation, transmission and distribution</td> </tr> <tr> <td>Class - 3510</td> <td>Electric power generation, transmission and distribution</td> </tr> <tr> <td>Sub Class - 35109</td> <td>Collection and distribution of electric energy to households, industrial, commercial and other users n.e.c.</td> </tr> </tbody> </table>		Level	Description	Section - F	CONSTRUCTION	Division - 43	Specialized construction activities	Group - 432	Electrical, plumbing and other construction installation activities	Class - 4321	Electrical installation	Sub Class - 43219	Other electrical installation n.e.c.	Level	Description	Section - D	ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY	Division - 35	ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY	Group - 351	Electric power generation, transmission and distribution	Class - 3510	Electric power generation, transmission and distribution	Sub Class - 35109	Collection and distribution of electric energy to households, industrial, commercial and other users n.e.c.
Level	Description																									
Section - F	CONSTRUCTION																									
Division - 43	Specialized construction activities																									
Group - 432	Electrical, plumbing and other construction installation activities																									
Class - 4321	Electrical installation																									
Sub Class - 43219	Other electrical installation n.e.c.																									
Level	Description																									
Section - D	ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY																									
Division - 35	ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY																									
Group - 351	Electric power generation, transmission and distribution																									
Class - 3510	Electric power generation, transmission and distribution																									
Sub Class - 35109	Collection and distribution of electric energy to households, industrial, commercial and other users n.e.c.																									

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof inside cargo jetty area.

EMD	₹ 53,719 /- (Rupees Fifty Three Thousand Seven Hundred Nineteen only)																				
	Through on line transfer in PNB bank account no. 2177002100004628 - Deendayal Port Authority - (IFSC code PUNB0217700). Scanned copy of RTGS no. and date of transfer may be uploaded on (n) procure website. In case of Micro and Small Enterprise (MSEs) holding valid certificate issued by any agencies/organization under The Ministry of Micro, Small and Medium Enterprises indicating the list of activity related to the subject tender as per National Industrial Classification-2008 mentioned in the table below only shall become eligible for exemption from payment of Tender fee/EMD. Such bidder shall upload the scanned copy of valid certificate along with Bid Securing Declaration Form (Form 7 in Section IV) in preliminary bid.																				
	<table border="1"> <thead> <tr> <th>Level</th> <th colspan="2">Description</th> </tr> </thead> <tbody> <tr> <td>Section - F</td> <td colspan="2">CONSTRUCTION</td> </tr> <tr> <td>Division - 43</td> <td colspan="2">Specialized construction activities</td> </tr> <tr> <td>Group - 432</td> <td colspan="2">Electrical, plumbing and other construction installation activities</td> </tr> <tr> <td>Class - 4321</td> <td colspan="2">Electrical installation</td> </tr> <tr> <td>Sub Class - 43219</td> <td colspan="2">Other electrical installation n.e.c.</td> </tr> </tbody> </table>			Level	Description		Section - F	CONSTRUCTION		Division - 43	Specialized construction activities		Group - 432	Electrical, plumbing and other construction installation activities		Class - 4321	Electrical installation		Sub Class - 43219	Other electrical installation n.e.c.	
	Level	Description																			
	Section - F	CONSTRUCTION																			
	Division - 43	Specialized construction activities																			
	Group - 432	Electrical, plumbing and other construction installation activities																			
	Class - 4321	Electrical installation																			
	Sub Class - 43219	Other electrical installation n.e.c.																			
	OR																				
	<table border="1"> <thead> <tr> <th>Level</th> <th colspan="2">Description</th> </tr> </thead> <tbody> <tr> <td>Section - D</td> <td colspan="2">ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY</td> </tr> <tr> <td>Division - 35</td> <td colspan="2">ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY</td> </tr> <tr> <td>Group - 351</td> <td colspan="2">Electric power generation, transmission and distribution</td> </tr> <tr> <td>Class - 3510</td> <td colspan="2">Electric power generation, transmission and distribution</td> </tr> <tr> <td>Sub Class - 35109</td> <td colspan="2">Collection and distribution of electric energy to households, industrial, commercial and other users n.e.c.</td> </tr> </tbody> </table>			Level	Description		Section - D	ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY		Division - 35	ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY		Group - 351	Electric power generation, transmission and distribution		Class - 3510	Electric power generation, transmission and distribution		Sub Class - 35109	Collection and distribution of electric energy to households, industrial, commercial and other users n.e.c.	
	Level	Description																			
	Section - D	ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY																			
	Division - 35	ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY																			
	Group - 351	Electric power generation, transmission and distribution																			
Class - 3510	Electric power generation, transmission and distribution																				
Sub Class - 35109	Collection and distribution of electric energy to households, industrial, commercial and other users n.e.c.																				
Last date of downloading																					
17/03/2025 upto 16:00																					
Last date and time of submission of E-tender																					
17/03/2025 upto 16:00 only on website																					
https://tender.nprocure.com:																					
Pre-bid meeting																					
Not Applicable																					

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof inside cargo jetty area.

Date and time for opening of E- tender	17/03/2025 at 16:00 hrs
Downloading websites	https://tender.nprocure.com , http://www.deendayalport.gov.in as well as http://www.eprocure.gov.in .
Corrigendum, if any, will be placed on websites only.	

-Sd/-
Executive Engineer (E)
Deendayal Port Authority

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

NOTICE INVITING ON LINE TENDER

Details about tender:

Department Name	Mechanical Engineering Department
Circle/ Division	Electrical Division, Nirman Building, Ground Floor, New Kandla-(Kutch)-370210
Tender Notice No.	EL/WK/2830
Name of Project	“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”
Name of Work	“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”
Estimated Contract Value (INR)	₹ 53,71,908/-
Period of Completion (in Months)	03 months from the date of issue of work order
Bidding Type	Open
Bid Call (Nos.)	One
Tender Currency Type	Single
Tender Currency Settings	Indian Rupee (INR)
Integrity Pact	<p>1) <i>The Employer / Authorized person of Employer shall sign the IP in the presence of a witness from their side, who shall also affix his /her signature thereof and then the same IP shall be uploaded by them on n-procure portal;</i></p> <p>2) <i>The potential bidders shall download and print the IP Agreement signed by the Employer and their witness and affix his/her signature on the IP Agreement in the presence of a witness from his/her side, who shall also affix his / her signature thereof. Having completed the signing procedure, the potential bidder shall uploaded the duly filled and signed IP Agreement on n-procure portal.</i></p> <p>3) <i>The procedure mentioned above regarding signing of Integrity Pact Agreement by both the parties (Employer and potential bidders) shall be completed online. However, In case of any technical glitch due to which of any potential bidders is unable to upload the IP Agreement, then he/she shall be submit the hard copy of the duly filled, signed IP Agreement, to the Department concerned of DPA with in a period of seven days and prior to opening of the Technical Bid, failing which Bid of potential bidders shall be treated as disqualified.</i></p>
Pre-Qualifying Criteria:	<p>PRE-QUALIFICATION CRITERIA FOR ELIGIBLE BIDDERS:</p> <p>The Bidders shall fulfill the following pre-qualification criteria:</p>

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

- a) Average Annual financial turnover during the last 3 years, ending 31st March of the previous financial year, should be at least ₹ **16.12** Lakh Certified by Chartered Accountant with UDIN Number.
- b) Experience of having successfully completed similar works during last 7 years ending last day of month previous to the one in which applications are invited should be either of the following:
- i) Three similar completed works each costing not less than the amount equal to ₹ **21.49** Lakh. **(Excluding GST)**
- Or
- ii) Two similar completed works each costing not less than the amount equal to ₹ **26.86** Lakh. **(Excluding GST)**
- Or
- iii) One similar completed work costing not less than the amount equal to ₹ **42.98** Lakh. **(Excluding GST)**
- c) In Case the similar work has been issued for any private body, the bidder will be required to produce the tax deducted at source (TDS) certificate indicating the income tax deducted by the client for that work, which will form the basis for assessing the value of completed work.
- Note:**
- (i) The particular row in the TDS certificate (Form 16A or Form 26AS), which indicates the credit of the payment received from the client, **should be highlighted.**
- (ii) Along with the TDS certificate, a declaration on the letter head of a Chartered Accountant with UDIN No. should be submitted giving details such as the name of bidder, the name of the client for which the bidder has carried out the work, name of work, work order no. and date, gross amount of the payment, net amount received from the client, TDS amount. **The statement should be signed by the Chartered Accountant.**
- (iii) In case any discrepancies between the TDS (Form 16A or Form 26AS) and the declaration given by the Chartered Accountant with regard to payment received from the client, it should be explained.
- D) The contractor shall have valid electrical contractor’s license and electrical supervisor license for carrying out electrical work of nature involved in this tender obtained from the competent authority of their respective states without which the tender shall not be accepted. Contractor shall submit certificate and copy of the license in lieu of the same for consideration.
- E) Upload duly signed document given at Section-VII towards evidence of site visit. (The bidder who has not physically visited the site and not uploaded document given at Section-VII, will be declared technically disqualified. The date of physical visit of site should be the date invariably

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

	prior to date of opening of preliminary bid.																								
Similar Work Defination	Similar works means: SITC of 11KV or above electrical distribution system with other ancillary works for any government/public sector unit/ private organization.																								
Joint Venture	Not Allowed																								
Rebate	Not applicable																								
Bid Document Fee:	<p>Rs. 1000 +180 (GST) Rs. 1180/- (One Thousand one Hundred Eighty Rupees Only)</p> <p>Through online transfer in PNB bank account no. 2177002100004628 - Deendayal Port Authority - (IFSC code PUNB0217700). Scanned copy of RTGS no. and date of transfer may be uploaded on –(n)procure website.</p> <p>In case of Micro and Small Enterprise (MSEs) holding valid certificate issued by any agencies/organization under The Ministry of Micro, Small and Medium Enterprises indicating the list of activity related to the subject tender as per National Industrial Classification-2008 mentioned in the table below only shall become eligible for exemption from payment of Tender fee/EMD. Such bidder shall upload the scanned copy of valid certificate along with Bid Securing Declaration Form (Form 7 in Section IV) in preliminary bid.</p> <table border="1"> <thead> <tr> <th>Level</th> <th>Description</th> </tr> </thead> <tbody> <tr> <td>Section – F</td> <td>CONSTRUCTION</td> </tr> <tr> <td>Division – 43</td> <td>Specialized construction activities</td> </tr> <tr> <td>Group - 432</td> <td>Electrical, plumbing and other construction installation activities</td> </tr> <tr> <td>Class – 4321</td> <td>Electrical installation</td> </tr> <tr> <td>Sub Class - 43219</td> <td>Other electrical installation n.e.c.</td> </tr> </tbody> </table> <p>Or</p> <table border="1"> <thead> <tr> <th>Level</th> <th>Description</th> </tr> </thead> <tbody> <tr> <td>Section – D</td> <td>ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY</td> </tr> <tr> <td>Division – 35</td> <td>ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY</td> </tr> <tr> <td>Group - 351</td> <td>Electric power generation, transmission and distribution</td> </tr> <tr> <td>Class – 3510</td> <td>Electric power generation, transmission and distribution</td> </tr> <tr> <td>Sub Class - 35109</td> <td>Collection and distribution of electric energy to households, industrial, commercial and other users n.e.c.</td> </tr> </tbody> </table>	Level	Description	Section – F	CONSTRUCTION	Division – 43	Specialized construction activities	Group - 432	Electrical, plumbing and other construction installation activities	Class – 4321	Electrical installation	Sub Class - 43219	Other electrical installation n.e.c.	Level	Description	Section – D	ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY	Division – 35	ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY	Group - 351	Electric power generation, transmission and distribution	Class – 3510	Electric power generation, transmission and distribution	Sub Class - 35109	Collection and distribution of electric energy to households, industrial, commercial and other users n.e.c.
Level	Description																								
Section – F	CONSTRUCTION																								
Division – 43	Specialized construction activities																								
Group - 432	Electrical, plumbing and other construction installation activities																								
Class – 4321	Electrical installation																								
Sub Class - 43219	Other electrical installation n.e.c.																								
Level	Description																								
Section – D	ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY																								
Division – 35	ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY																								
Group - 351	Electric power generation, transmission and distribution																								
Class – 3510	Electric power generation, transmission and distribution																								
Sub Class - 35109	Collection and distribution of electric energy to households, industrial, commercial and other users n.e.c.																								
Bid Document Fee Payable To:	Through on-line transfer in PNB bank account no. 2177002100004628 - Deendayal Port Authority - (IFSC code PUNB0217700), Kandla branch. Scanned copy of RTGS no. and date of transfer may be uploaded on (n) procure website. In case of Micro and Small Enterprise (MSEs) holding valid certificate issued by any agencies/organization under The Ministry of Micro, Small and Medium Enterprises indicating the list of activity related to the																								

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

	<p>subject tender as per National Industrial Classification 2008 mentioned in the table below only shall become eligible for exemption from payment of Tender fee/EMD. Such bidder shall upload the scanned copy of valid certificate along with Bid Securing Declaration Form-7 failing which the bid shall be considered non-responsive in preliminary bid.</p> <table border="1" data-bbox="480 415 1485 699"> <thead> <tr> <th>Level</th> <th>Description</th> </tr> </thead> <tbody> <tr> <td>Section - F</td> <td>CONSTRUCTION</td> </tr> <tr> <td>Division - 43</td> <td>Specialized construction activities</td> </tr> <tr> <td>Group - 432</td> <td>Electrical, plumbing and other construction installation activities</td> </tr> <tr> <td>Class - 4321</td> <td>Electrical installation</td> </tr> <tr> <td>Sub Class - 43219</td> <td>Other electrical installation n.e.c.</td> </tr> </tbody> </table> <p>OR</p> <table border="1" data-bbox="480 772 1485 1094"> <thead> <tr> <th>Level</th> <th>Description</th> </tr> </thead> <tbody> <tr> <td>Section - D</td> <td>ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY</td> </tr> <tr> <td>Division - 35</td> <td>ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY</td> </tr> <tr> <td>Group - 351</td> <td>Electric power generation, transmission and distribution</td> </tr> <tr> <td>Class - 3510</td> <td>Electric power generation, transmission and distribution</td> </tr> <tr> <td>Sub Class - 35109</td> <td>Collection and distribution of electric energy to households, industrial, commercial and other users n.e.c.</td> </tr> </tbody> </table>	Level	Description	Section - F	CONSTRUCTION	Division - 43	Specialized construction activities	Group - 432	Electrical, plumbing and other construction installation activities	Class - 4321	Electrical installation	Sub Class - 43219	Other electrical installation n.e.c.	Level	Description	Section - D	ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY	Division - 35	ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY	Group - 351	Electric power generation, transmission and distribution	Class - 3510	Electric power generation, transmission and distribution	Sub Class - 35109	Collection and distribution of electric energy to households, industrial, commercial and other users n.e.c.
Level	Description																								
Section - F	CONSTRUCTION																								
Division - 43	Specialized construction activities																								
Group - 432	Electrical, plumbing and other construction installation activities																								
Class - 4321	Electrical installation																								
Sub Class - 43219	Other electrical installation n.e.c.																								
Level	Description																								
Section - D	ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY																								
Division - 35	ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY																								
Group - 351	Electric power generation, transmission and distribution																								
Class - 3510	Electric power generation, transmission and distribution																								
Sub Class - 35109	Collection and distribution of electric energy to households, industrial, commercial and other users n.e.c.																								
<p>Bid Security/ EMD (INR) :</p>	<p>₹ 53,719/- (Rupees Fifty Three Thousand Seven Hundred Nineteen only)</p> <p>Through on-line transfer in PNB bank account no. 2177002100004628 - Deendayal Port Authority - (IFSC code PUNB0217700), Kandla branch. Scanned copy of RTGS no. and date of transfer may be uploaded on (n) procure website. In case of Micro and Small Enterprise (MSEs) holding valid certificate issued by any agencies/organization under The Ministry of Micro, Small and Medium Enterprises indicating the list of activity related to the subject tender as per National Industrial Classification 2008 mentioned in the table below only shall become eligible for exemption from payment of Tender fee/EMD. Such bidder shall upload the scanned copy of valid certificate along with Bid Securing Declaration Form-7 failing which the bid shall be considered non-responsive in preliminary bid.</p> <p>OR</p> <table border="1" data-bbox="480 1690 1485 1971"> <thead> <tr> <th>Level</th> <th>Description</th> </tr> </thead> <tbody> <tr> <td>Section - F</td> <td>CONSTRUCTION</td> </tr> <tr> <td>Division - 43</td> <td>Specialized construction activities</td> </tr> <tr> <td>Group - 432</td> <td>Electrical, plumbing and other construction installation activities</td> </tr> <tr> <td>Class - 4321</td> <td>Electrical installation</td> </tr> <tr> <td>Sub Class - 43219</td> <td>Other electrical installation n.e.c.</td> </tr> </tbody> </table>	Level	Description	Section - F	CONSTRUCTION	Division - 43	Specialized construction activities	Group - 432	Electrical, plumbing and other construction installation activities	Class - 4321	Electrical installation	Sub Class - 43219	Other electrical installation n.e.c.												
Level	Description																								
Section - F	CONSTRUCTION																								
Division - 43	Specialized construction activities																								
Group - 432	Electrical, plumbing and other construction installation activities																								
Class - 4321	Electrical installation																								
Sub Class - 43219	Other electrical installation n.e.c.																								

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

	<table border="1"> <thead> <tr> <th>Level</th> <th>Description</th> </tr> </thead> <tbody> <tr> <td>Section - D</td> <td>ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY</td> </tr> <tr> <td>Division - 35</td> <td>ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY</td> </tr> <tr> <td>Group - 351</td> <td>Electric power generation, transmission and distribution</td> </tr> <tr> <td>Class - 3510</td> <td>Electric power generation, transmission and distribution</td> </tr> <tr> <td>Sub Class - 35109</td> <td>Collection and distribution of electric energy to households, industrial, commercial and other users n.e.c.</td> </tr> </tbody> </table>	Level	Description	Section - D	ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY	Division - 35	ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY	Group - 351	Electric power generation, transmission and distribution	Class - 3510	Electric power generation, transmission and distribution	Sub Class - 35109	Collection and distribution of electric energy to households, industrial, commercial and other users n.e.c.												
Level	Description																								
Section - D	ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY																								
Division - 35	ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY																								
Group - 351	Electric power generation, transmission and distribution																								
Class - 3510	Electric power generation, transmission and distribution																								
Sub Class - 35109	Collection and distribution of electric energy to households, industrial, commercial and other users n.e.c.																								
<p>Bid Security/ EMD (INR) In Favor Of :</p>	<p>Through on-line transfer in PNB bank account no. 2177002100004628 - Deendayal Port Authority - (IFSC code PUNB0217700), Kandla branch. Scanned copy of RTGS no. and date of transfer may be uploaded on (n) procure website. In case of Micro and Small Enterprise (MSEs) holding valid certificate issued by any agencies/organization under The Ministry of Micro, Small and Medium Enterprises indicating the list of activity related to the subject tender as per National Industrial Classification 2008 mentioned in the table below only shall become eligible for exemption from payment of Tender fee/EMD. Such bidder shall upload the scanned copy of valid certificate along with Bid Securing Declaration Form-7 failing which the bid shall be considered non-responsive in preliminary bid.</p> <table border="1"> <thead> <tr> <th>Level</th> <th>Description</th> </tr> </thead> <tbody> <tr> <td>Section - F</td> <td>CONSTRUCTION</td> </tr> <tr> <td>Division - 43</td> <td>Specialized construction activities</td> </tr> <tr> <td>Group - 432</td> <td>Electrical, plumbing and other construction installation activities</td> </tr> <tr> <td>Class - 4321</td> <td>Electrical installation</td> </tr> <tr> <td>Sub Class - 43219</td> <td>Other electrical installation n.e.c.</td> </tr> </tbody> </table> <p>OR</p> <table border="1"> <thead> <tr> <th>Level</th> <th>Description</th> </tr> </thead> <tbody> <tr> <td>Section - D</td> <td>ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY</td> </tr> <tr> <td>Division - 35</td> <td>ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY</td> </tr> <tr> <td>Group - 351</td> <td>Electric power generation, transmission and distribution</td> </tr> <tr> <td>Class - 3510</td> <td>Electric power generation, transmission and distribution</td> </tr> <tr> <td>Sub Class - 35109</td> <td>Collection and distribution of electric energy to households, industrial, commercial and other users n.e.c.</td> </tr> </tbody> </table>	Level	Description	Section - F	CONSTRUCTION	Division - 43	Specialized construction activities	Group - 432	Electrical, plumbing and other construction installation activities	Class - 4321	Electrical installation	Sub Class - 43219	Other electrical installation n.e.c.	Level	Description	Section - D	ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY	Division - 35	ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY	Group - 351	Electric power generation, transmission and distribution	Class - 3510	Electric power generation, transmission and distribution	Sub Class - 35109	Collection and distribution of electric energy to households, industrial, commercial and other users n.e.c.
Level	Description																								
Section - F	CONSTRUCTION																								
Division - 43	Specialized construction activities																								
Group - 432	Electrical, plumbing and other construction installation activities																								
Class - 4321	Electrical installation																								
Sub Class - 43219	Other electrical installation n.e.c.																								
Level	Description																								
Section - D	ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY																								
Division - 35	ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY																								
Group - 351	Electric power generation, transmission and distribution																								
Class - 3510	Electric power generation, transmission and distribution																								
Sub Class - 35109	Collection and distribution of electric energy to households, industrial, commercial and other users n.e.c.																								
<p>Bid Document Downloading Start Date</p>	<p>17/02/2025</p>																								
<p>Bid Document Downloading End</p>	<p>17/03/2025 up to 16:00 Hrs.</p>																								

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

Date																											
Date & Place of Pre Bid Meeting	Not Applicable																										
Last Date & Time for Receipt of Bids	17/03/2025 @ 15:30 Hrs.																										
Bid Validity Period	120 Days																										
Condition	<p>(1) Tender Fee : Rs. 1000 +180 (GST)= 1180/- Present rate of GST is 18% (non- refundable)/-(One thousand one Hundred eighty rupees Only)</p> <p>Through on line transfer in PNB bank account no. 2177002100004628 - Deendayal Port Authority - (IFSC code PUNB0217700). Scanned copy of RTGS no.and date of transfer may be uploaded on—(n)procure website.</p> <p>In case of Micro and Small Enterprise (MSEs) holding valid certificate issued by any agencies/organization under The Ministry of Micro, Small and Medium Enterprises indicating the list of activity related to the subject tender as per National Industrial Classification-2008 mentioned in the table below only shall become eligible for exemption from payment of Tender fee/EMD.Such bidder shall upload the scanned copy of valid certificate along with Bid Securing Declaration Form (Form 7 in Section IV) in preliminary bid.</p> <table border="1"> <thead> <tr> <th>Level</th> <th>Description</th> </tr> </thead> <tbody> <tr> <td>Section - F</td> <td>CONSTRUCTION</td> </tr> <tr> <td>Division - 43</td> <td>Specialized construction activities</td> </tr> <tr> <td>Group - 432</td> <td>Electrical, plumbing and other construction installation activities</td> </tr> <tr> <td>Class - 4321</td> <td>Electrical installation</td> </tr> <tr> <td>Sub Class - 43219</td> <td>Other electrical installation n.e.c.</td> </tr> <tr> <td>OR</td> <td></td> </tr> </tbody> </table> <table border="1"> <thead> <tr> <th>Level</th> <th>Description</th> </tr> </thead> <tbody> <tr> <td>Section - D</td> <td>ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY</td> </tr> <tr> <td>Division - 35</td> <td>ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY</td> </tr> <tr> <td>Group - 351</td> <td>Electric power generation, transmission and distribution</td> </tr> <tr> <td>Class - 3510</td> <td>Electric power generation, transmission and distribution</td> </tr> <tr> <td>Sub Class - 35109</td> <td>Collection and distribution of electric energy to households, industrial, commercial and other users n.e.c.</td> </tr> </tbody> </table> <p>2) EMD: ₹ 53,719/- (Rupees Fifty Three Thousand Seven Hundred Nineteen only)</p> <p>Through the form of Bank Guarantees (as per enclosed format Form-6 In Section IV) to be uploaded on—(n)procure website.</p>	Level	Description	Section - F	CONSTRUCTION	Division - 43	Specialized construction activities	Group - 432	Electrical, plumbing and other construction installation activities	Class - 4321	Electrical installation	Sub Class - 43219	Other electrical installation n.e.c.	OR		Level	Description	Section - D	ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY	Division - 35	ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY	Group - 351	Electric power generation, transmission and distribution	Class - 3510	Electric power generation, transmission and distribution	Sub Class - 35109	Collection and distribution of electric energy to households, industrial, commercial and other users n.e.c.
Level	Description																										
Section - F	CONSTRUCTION																										
Division - 43	Specialized construction activities																										
Group - 432	Electrical, plumbing and other construction installation activities																										
Class - 4321	Electrical installation																										
Sub Class - 43219	Other electrical installation n.e.c.																										
OR																											
Level	Description																										
Section - D	ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY																										
Division - 35	ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY																										
Group - 351	Electric power generation, transmission and distribution																										
Class - 3510	Electric power generation, transmission and distribution																										
Sub Class - 35109	Collection and distribution of electric energy to households, industrial, commercial and other users n.e.c.																										

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

Through on line transfer in PNB bank account no. 2177002100004628 - Deendayal Port Authority - (IFSC code PUNB0217700). Scanned copy of RTGS no. and date of transfer may be uploaded on –(n)procure website.

In case of Micro and Small Enterprise (MSEs) holding valid certificate issued by any agencies/organization under The Ministry of Micro, Small and Medium Enterprises indicating the list of activity related to the subject tender as per National Industrial Classification-2008 mentioned in the table below only shall become eligible for exemption from payment of Tender fee/EMD. Such bidder shall upload the scanned copy of valid certificate **along with Bid Securing Declaration Form (Form 7 in Section IV)** in preliminary bid.

Level	Description
Section - F	CONSTRUCTION
Division - 43	Specialized construction activities
Group - 432	Electrical, plumbing and other construction installation activities
Class - 4321	Electrical installation
Sub Class - 43219	Other electrical electrical installation n.e.c.

OR

Level	Description
Section - D	ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY
Division - 35	ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY
Group - 351	Electric power generation, transmission and distribution
Class - 3510	Electric power generation, transmission and distribution
Sub Class - 35109	Collection and distribution of electric energy to households, industrial, commercial and other users n.e.c.

3) Integrity Pact -

- 1) *The Employer / Authorized person of Employer shall sign the IP in the presence of a witness from their side, who shall also affix his /her signature thereof and then the same IP shall be uploaded by them on n-procure portal;*
- 2) *The potential bidders shall download and print the IP Agreement signed by the Employer and their witness and affix his/her signature on the IP Agreement in the presence of a witness from his/her side, who shall also affix his / her signature thereof. Having completed the signing procedure, the potential bidder shall upload the duly filled and signed IP Agreement on n-procure portal.*
- 3) *The procedure mentioned above regarding signing of Integrity Pact Agreement by both the parties (Employer and potential bidders) shall be completed online. However, In case of any technical glitch due to which of any potential bidders is unable to upload the IP Agreement,*

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

	<p><i>then he/she shall be submit the hard copy of the duly filled, signed IP Agreement, to the Department concerned of DPA with in a period of seven days and prior to opening of the Technical Bid, failing which Bid of potential bidders shall be treated as disqualified.</i></p> <p>Integrity Pact is required to be submitted in preliminary bid, failing which the bid shall be treated as non-responsive and shall be rejected.</p> <p>Accordingly, offer of those bidders shall only be opened whose EMD, Tender Fee and Integrity pact (duly signed by principal, bidder and witness in proper format attached) and along with Bid Securing Declaration Form (Form 7 in Section IV) are received electronically.</p> <p>However, for the purpose of realization, bidder shall send the same in original to XEN (E) at the time of tender opening or send the same by hand/courier/RPAD/Speed post so as to reach the Executive Engineer (E), Electrical Division, Port & Custom Building, Ground Floor, New Kandla-(Kutch)-370210 within 07 days from the last date of opening without fail, without which the bid shall be treated as non-responsive.</p>
Remarks	The hard copies should reach to the Electrical Division within 07 days from the date of opening of preliminary bid.
Bid Opening Date	Technical Bid will be opened on xx/xx/2024 @ 14:30 Hrs. Date of opening of price bid shall be notified after scrutiny and evaluation of Technical Bid.
Documents required to be submitted by scanning through online	<ul style="list-style-type: none"> a. Documents in support of fulfilling Qualifying Criteria as indicated above. b. EMD -As indicated above. c. Tender fee - As indicated above. d. Integrity pact (duly signed by bidder and witness) e. Documents Mentioned in Eligibility Criteria. f. Along with Bid Securing Declaration Form (Form 7 in Section IV) g. Valid Electrical Contractor License issued by respective State / Central Govt.
Officer- Inviting Bids:	Executive Engineer (E), Electrical Division, Port & Custom Building, Ground Floor, New Kandla-(Kutch)-370210
Bid Opening Authority :	Executive Engineer (E)
Address:	Executive Engineer (E), Electrical Division, Port & Custom Building, Ground Floor, New Kandla-(Kutch)-370210
Contact Details :	Executive Engineer (E), Electrical Division, Port & Custom Building, Ground Floor, New Kandla (Kutch)-370210 Phone: 02836-270209, 270342. Fax No. 02836 270184.
Corrigendum, if any, will be placed on websites only.	

In case, bidders need any clarifications or if training is required to participate in online Tenders, they can contact (n) Procure Support team at following address: -

(n) Code Solutions-A division of GNFC Ltd.,

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

(n) Procure Cell 403, GNFC Info tower, S.G. Road, Bodakdev, Ahmadabad – 380054 (Gujarat)

Contact Details:

Airtel: +91-79-40007501, 40007512, 40007516, 40007517, 40007525

BSNL: +91-79-26854511, 26854512, 26854513 (EXT: 501, 512, 516, 517, 525)

Reliance: +91-79-30181689 Fax: +91-79-26857321, 40007533

E-mail: nprocure@gnvfc.net

TOLL FREE NUMBER: 1-800-233-1010 (EXT: 501, 512, 516, 517, 525)

-Sd/-

**Executive Engineer (E)
Deendayal Port Authority**

SECTION – I

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

INSTRUCTION TO BIDDERS

A. GENERAL

1. Scope of Bid

1.1 The Executive Engineer (Electrical) Deendayal Port Authority invites bids by E-Tendering from the interested eligible bidder for the work as mentioned in the notice inviting online tender. All bids shall be completed and submitted on-line in accordance with instruction to the bidders.

1.2 The successful bidder will be expected to complete the works by the intended completion period.

2. Source of funds

2.1 The employer has arranged the funds from the internal resources and will have sufficient funds in India Currency for execution of the work.

3. Eligible Bidders

Only eligible bidders fulfilling all the requirements as mentioned in the Notice Inviting Online Tender may participate in the subject Tender. Successful completion of “Similar Works” only shall be considered for evaluation of eligibility criteria.

3.1 The invitation for Bids is open to all eligible bidders meeting the eligibility criteria as defined in clause regarding Eligibility Criteria.

3.2 All bidders shall fill the forms provided in Section – IV- Part – I “To be submitted by Bidders with their Bids”.

3.3 Government-owned enterprises may participate if they are legally and financially autonomous, operate under commercial law and are not a dependent agency of the employer subject to fulfilment of Minimum Qualifying criteria.

3.4 Bidders shall not be under a declaration of ineligibility for corrupt and fraudulent practices issued by the employer.

4. Eligibility Criteria:

4.1 The Bidders shall fulfil the following pre-qualification criteria:-

Sr. No	Particulars	Supporting Documents
(a)	Average Annual financial turnover during the last 3 years, ending 31 st March of the previous financial year, should be at least ₹ 16.12 Lakh Certified by Chartered Accountant with UDIN number.	Certificate should be issued by the Chartered Accountant with UDIN number
(b)	Experience of having successfully completed similar works during last 7 years ending last day of month previous to the one in which applications are invited should be either of the following: (i) Three similar completed works each costing not less than the amount	(a) A copy of the completion certificate in respect of the successfully completed similar work. (b) A copy of detail work order should also be submitted for which the bidder is submitting the completion certificate.

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

	<p>equal to ₹ 21.49 Lakh. (Excluding GST)</p> <p style="text-align: center;">Or</p> <p>(ii) Two similar completed works each costing not less than the amount equal to ₹ 26.86 Lakh. (Excluding GST)</p> <p style="text-align: center;">Or</p> <p>(iii) One similar completed work costing not less than the amount equal to ₹ 42.98 Lakh. (Excluding GST)</p>	<p>Such completion certificate should be issued on the letter head of the client and invariably reflect the following details:-</p> <ol style="list-style-type: none"> 1) Name of Contractor 2) Name of Work 3) No. of work order/agreement and date 4) Contract value 5) Contract period 6) Date of commencement of work 7) Date of completion 8) Value of Work executed during the contract period/original contract period 9) Date of issue of completion certificate. <p>c). In Case the similar work has been issued for any private body, the bidder will be required to produce the tax deducted at source (TDS) certificate indicating the income tax deducted by the client for that work, which will form the basis for assessing the value of completed work. Along with the TDS certificate, a statement Should be submitted giving details showing the name of the client, gross amount of the work, TDS amount and net payment received. The statement should be signed By the Chartered Accountant.</p>
(c)	<p>In Case the similar work has been issued for any private body, the bidder will be required to produce the tax deducted at source (TDS) certificate indicating the income tax deducted by the client for that work, which will form the basis for assessing the value of completed work.</p> <p>Note:</p> <ol style="list-style-type: none"> (i) The particular row in the TDS certificate (Form 16A or Form 26AS), which indicates the credit of the payment received from the client, should be highlighted. (ii) Along with the TDS certificate, a declaration on the letter head of a Chartered Accountant should be submitted giving details such as the name of bidder, the name of the client for which the bidder has carried out the work, name of work, work order no. and date, gross amount of the payment, net amount received from the client, TDS amount. The statement should be signed by the Chartered Accountant. (iii) In case any discrepancies between the TDS (Form 16A or Form 26AS) and the declaration given by the Chartered Accountant with regard to payment 	

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

	received from the client, it should be explained.	
(d)	The contractor shall have valid electrical contractor’s license and electrical supervisor license for carrying out electrical work of nature involved in this tender obtained from the competent authority of their respective states without which the tender shall not be accepted. Contractor shall submit certificate and copy of the license in lieu of the same for consideration.	
(e)	Upload duly signed document given at Section-VII towards evidence of site visit. (The bidder who has not physically visited the site and not uploaded document given at Section-VII, will be declared technically disqualified. The date of physical visit of site should be the date invariably prior to date of opening of preliminary bid.	
(g)	Similar works means:	SITC of 11KV or above electrical distribution system with ancillary electrical work for any government/public sector unit/private organization.

4.2 All bidders shall scan and forward the following information and documents with their bids.

- a. Copies of original documents defining the constitution or legal status, place of registration, and principal place of business, written power of attorney of the signatory of the Bid to commit the Bidder.
- b. Total monetary value of similar works performed for each of the last seven years ending last day of month previous the one in which applications are invited
- c. Experience in works of a similar nature and size for each of the last seven years, and details of works underway or contractually committed, and Employers who may be contacted for further information on those contracts.
- d. Reports on the financial standing of the Bidder, such as profit and loss statements and auditor’s reports for the past three years ending 31st March of the previous financial year.
- e. Duly filled Forms mentioned in Section – IV- Part – I.
- f. PAN, Registration with GST, Provident Fund Authorities.
- g. Valid Electrical Contractor License issued by respective State / Central Govt. (Without uploading of Valid Electrical Contractor License bid will be considered irresponsible)**
- h. EMD - Through on line transfer in PNB bank account no. 2177002100004628 - Deendayal Port Authority - (IFSC code PUNB0217700). Scanned copy of RTGS no. and date of transfer may be uploaded on –(n)procure website.

In case of Micro and Small Enterprise (MSEs) holding valid certificate issued by any agencies/organization under The Ministry of Micro, Small and Medium Enterprises indicating the list of

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

activity related to the subject tender as per National Industrial Classification-2008 mentioned in the table below only shall become eligible for exemption from payment of Tender fee/EMD.Such bidder shall upload the scanned copy of valid certificate **along with Bid Securing Declaration Form (Form 7 in Section IV)** in preliminary bid.

Level	Description
Section - D	ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY
Division - 35	ELECTRICITY, GAS, STEAM AND AIRCONDITION SUPPLY
Group - 351	Electric power generation, transmission and distribution
Class - 3510	Electric power generation, transmission and distribution
Sub Class - 35109	Collection and distribution of electric energy to households, industrial, commercial and other users n.e.c.
Section - F	CONSTRUCTION
Division - 43	Specialized construction activities
Group - 432	Electrical, plumbing and other construction installation activities
Class - 4321	Electrical installation
Sub Class - 43219	Other electrical installation n.e.c.

- i. Tender fee in form of Digital Transfer only.
- j. Information regarding any litigation, current or during the last five years, in which the Bidder is involved, the parties concerned, and disputed amount.
- k. A certificate by the bidder that they have not been banned / black listed by any govt. Agency.
- l. Power of attorney (dully accompanied by resolution of Board in case of company).
- m. Qualifications and experience of key site management and technical personnel proposed for the contract.
- n. The proposed methodology and program of work, backed with equipment planning and deployment, duly supported with broad calculations and quality control procedures proposed to be adopted justifying their capability of execution and completion of the work as per technical specifications within the stipulated period of completion as per milestones.
- o. The completion certification should invariably mention the reference no. of work order, the date of completion and contract value.
- p. The copy of the work order shall also be submitted for which the bidder is submitting completion certificate.
- q. In case the similar work has been executed for any private body, the bidder will produce the tax deducted at source (TDS) certificate indicating the income tax deducted by the client for that work,

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

which will form the basis for assessing the value of completed work.

- r. Bidders should give an undertaking that the documents submitted by them in support of their credentials are genuine and DPA is at liberty to take any action against the bidder if the said documents are found to be non-genuine.
- s. Bidders should give an undertaking that they will comply to the specifications of the work including terms and conditions in total without any deviation.
- t. Duly signed Integrity pact agreement by the bidder and witness (also to be arranged by bidder) to be submitted in preliminary bid.
- u. Bid Securing Declaration Form for MSE’s (Form 7 in Section IV) to be submitted in preliminary bid.

4.3 Even though the bidder meets the above qualifying criteria, they are subject to be disqualified if they have:

- Made misleading or false representations in the forms, statements and attachments submitted in proof of the qualification requirements: and/or
- Record of poor performance such as abandoning the works, non – completion of the contract.

5. One Bid per Bidder

5.1 Each bidder shall submit only one bid. A bidder who submits more than one Bid will be disqualified. The bidder can be disqualified from bidding for any contract with DPA for a period of three years from the date of notification.

6. Joint Venture (not applicable)

In case of association in the form of consortium or joint venture agreement, the members of the association shall nominate one of the members as “lead partner” for participating in the tender and signing all the documents related therewith up to signing of agreement and execution of all the contractual obligations there after (in case of award of contract). All the partners of the association must also, jointly and severally, be responsible for satisfactory execution and performance of the contract. The firms with at least 26% equity holding each are allowed to jointly meet the legibility criteria.

7. Cost of Bidding

7.1 The Bidder shall bear all costs associated with the preparation and submission of its Bid and employer will in no case be responsible and liable for those costs regardless of the conduct or outcome of the bidding process.

8. Site Visit

8.1 The Bidder, at his own responsibility and risk is encouraged to visit and examine the site of work and its surroundings and obtain all information that may be necessary for preparing the Bid and entering into a contract for the works. The costs of visiting the site shall be at the Bidders’ own expense.

B. Bidding Documents

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

1. Content of Bidding Documents

1.1 The set of bidding documents comprises the documents listed in the below and addenda issued in accordance with clause-19:

Invitation for Bids (NIT)

Bid Reference No. EL/WK/2830

- **NIT** : **Invitation for Bids**
- **Section I** : **Instruction to Bidders**
- **Section II** : **General Conditions of Contract**
- **Section III** : **Special Conditions of Contract**
- **Section IV** : **Forms of Bid**
- **Section V** : **Scope of Work & Technical Specifications**
- **SECTION VI** : **Bill of Quantities**
- **Section VII** : **Evidence Towards Site Visit**
- **Section VIII** : **Approved Make List for Electrical Items**
- **Section IX** : **Integrity pact**

1.2 The bidding documents shall be downloaded. The documents should be completely filled and submitted through on line E – Tendering process.

1.3 The bidder is expected to examine carefully all instructions, conditions of contract, forms, terms, technical specifications, bill of quantities, in the bid document. Failure to comply with the requirements of the bid document shall be at the bidder’s own risk. Bids which are not substantially responsive to the requirements of the tender documents shall be rejected.

2. Clarifications of the Bidding Documents

2.1 A prospective bidder requiring any clarification of the bidding documents may notify the employer in writing. The employer may respond to any request for clarification which are received within seven days prior to date of pre-bid meeting. The clarifications shall be uploaded on Website <https://tender.nprocure.com>, www.deendayalport.gov.in, and www.eprocure.gov.in.

2.2 Pre-Bid meeting: (Modified in clause no. of Section –III)

10.2.1 The bidder or his official representative may attend pre-bid meeting to be held on XX/XX/2025 @ 16:00 hrs. at Old Board Room, A.O Building, Gandhidham. The bidders/representative of bidders who wish to attend the Pre-Bid meeting shall furnish the authority letter on the letter head of Bidder, for attending the Pre-Bid Meeting on behalf of bidder at the time of Pre-Bid Meeting.

10.2.2 The purpose of the meeting will be to clarify issues related to work and tender conditions.

Pre – Bid clarifications will be uploaded in <https://tender.nprocure.com>, www.deendayalport.gov.in or www.eprocure.gov.in website without disclosing source of enquiry.

10.2.3 Non-attendance at the pre-bid meeting will not be a cause for disqualification of a bidder.

10.2.4 At any time prior to the deadline for submission of Bids, employer may, for any reason, whether

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

at its own initiative or in response to a clarification sought by any prospective bidder, modify the bidding documents by amendment / addendum.

10.2.5 Those bidders who download the tender document from the website shall be solely responsible to check the web site for the amendment issued in shape of Corrigendum and/or Addendum.

3. Language of Bid

All documents relating to the bid shall be in the English language.

4. Documents comprising the Bid

The bid submitted by the bidder shall comprise the following:

A) Technical Bid:

i) Bid Security i.e. EMD and Tender Fees and Integrity Pact (Preliminary Bid) and **along with Bid Securing Declaration Form for MSE’s (Form 7 in Section IV)**

ii) Qualification information in accordance to clause of **Eligibility Criteria** shall be submitted.

B) Financial Bid :

(i) Bill of Quantities duly filled and digitally signed by bidder.

5. Bid Prices

5.1 The rates and prices quoted by the bidder shall be fixed for the duration of the contract and shall not be subject to adjustment on any account.

5.2 The prices shall be quoted inclusive of all Taxes, Duties, and other incidentals charges like Transportation, Loading, Unloading, Boarding & Lodging etc. except GST and shall remain firm till completion of work. All other duties, taxes, cesses applicable if any, shall be borne by the contractor

6. Currencies of Bid and Payment

The unit rates and the prices shall be quoted by the bidder in Indian Rupees only.

7. Bid Validity

7.1 Bids shall remain valid for a period of 120 days from the date of opening of the Technical Bid. A bid valid for a shorter period shall be rejected by the employer as Non-responsive.

7.2 In exceptional circumstances, prior to expiry of the original time limit, the employer may request the bidders to extend the period of validity for additional period. The request and the bidders’ responses shall be made in writing.

7.3 A bidder agreeing to the request will not be permitted to modify his bid.

8. Bid Security

8.1 EARNEST MONEY DEPOSIT (EMD)

v. The tender shall be accompanied by Earnest Money Deposit of **Rs. 53,719 /- (Rupees Fifty Three**

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

thousand Seven Hundred Nineteen Only) he tender not accompanied with EMD shall not be considered & their technical and price bid will be returned un-opened. Through on line transfer in PNB bank account no. 2177002100004628 - Deendayal Port Authority - (IFSC code PUNB0217700). Scanned copy of RTGS no. and date of transfer may be uploaded on—(n) procure website.

In case of Micro and Small Enterprise (MSEs) holding valid certificate issued by any agencies/organization under The Ministry of Micro, Small and Medium Enterprises indicating the list of activity related to the subject tender as per National Industrial Classification-2008 mentioned in the table below only shall become eligible for exemption from payment of Tender fee/EMD. Such bidder shall upload the scanned copy of valid certificate **along with Bid Securing Declaration Form (Form 7 in Section IV)** in preliminary bid in order to become eligible for exemption from payment of EMD. It may be noted that exemption certificate issued by any other authority will not be entertained.

(a) EMD

- (i) The EMD of successful Bidder will be refunded on submission of performance guarantee (in Form 10 of SECTION IV) as per the tender clause and executing the agreement (in Form 9 of SECTION IV) as per tender clause. The EMD of unsuccessful bidders other than L1 & L2 be refunded immediately after ranking of Bids. Earnest Money of L2 bidder shall be refunded immediately after entering into agreement with L1 and acceptance of Performance Guarantee from L1.
- (ii) EMD will be refunded Suo-motto without any application from the Bidders.
- (iii) The EMD of successful bidder will be discharged (refunded) after he has signed the Agreement and furnished the required Performance Guarantee.
- (iv) Earnest Money Deposit will not carry any interest.

(b) Bid Security i.e. EMD will be forfeited if: **Necessary action shall be taken to disqualify the bidder from bidding process of any contract with DPA for a period of 03 years, if:**

- (i) The bidder withdraws the Bid after Bid opening during the bid validity;
- (ii) The bidder does not accept the correction of the Bid-Price, pursuant to any arithmetic errors;
- (iii) The successful Bidder fails within the specified time limit to
 - a) sign the Agreement or
 - b) furnish the required performance Guarantee
- (iv) The bidder submits more than one bid
- (v) If L-1 Bidder fail to justify the abnormal rate quoted by them or rates not quoted considering ALC/CLC rate of labour prevailing at the time of bidding, offer of the L-1 bidder shall be rejected, EMD shall be forfeited and they will be liable for debarring further tender from the DPA bidding for a period of three years.

9. Alternative Proposals by Bidders

9.1 Conditional offer or Alternative offers will not be considered in the process of tender evaluation.

10. Format and Signing of Bid

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

10.1 The Price Bid to be submitted on-line shall be signed digitally by a person or persons duly authorized to sign on behalf the Bidders.

11. Amendment of Bidding Documents

11.1 Before the deadline for submission of bids, the Employer may modify the bidding documents by using addenda.

11.2 Any addendum thus issued shall be part of the bidding documents and shall be communicated inwriting or by cable to all the purchasers of the bidding documents. Prospective bidders shall acknowledge the receipt of each addendum by cable to the Employer.

11.3 To give prospective bidders reasonable time in which to take an addendum in to account in preparing their bids, the Employer shall extend as necessary the deadline for submission of bids.

D. Submission of Bids.

12. Submission of Bids

Bidders who wish to participate in the tender will have to procure/should have legally valid Digital Certificate, as per Information Technology Act-2000, using which they can sign their electronic bids. The bidders can procure the Digital Certificate from (n) code solutions a division of GNFC Ltd, who are licensed certifying authority by Government of India. All bids should be digitally signed. For details regarding Digital signature certificate and related matters, the bidder may contact the following address:

(n) code Solutions, A
Division of GNFC, 301
GNFC Infotower,
Bodakdev, Ahmedabad. Tel.
91 79 26857316/17/18
Fax: 91 79 26857321
Mobile: 9327084190 / 9898589652.
E-mail: nprocure@gnvfc.net.

The accompaniments to the tender documents as described under Clause **4.2** shall be Scanned and submitted On-Line along with Tender documents. **However, the originals/attested hardcopies along with tender documents (except Price Bid), signed on bottom of each page in token of acceptance of Tender Conditions** and shall have to be forwarded subsequently so as to reach the office of Executive Engineer(Electrical) on same day & time of opening of the tenders.

12.1 The envelopes shall be addressed to:

(a) Executive Engineer(E)
Deendayal Port Authority,
Electrical Division, Ground Floor,
Port & Customs Building,
New Kandla – 370210.Gujarat-State.

(b) bear the following identification:

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

Accompaniments for “Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

Bid reference No EL/WK/2830

Name and address of the bidder.

13. Deadline of Submission of the Bids

- 13.1 Bids must be received by the employer in On-Line System at websites <https://tender.nprocure.com> not later than 15:00 Hrs on XX/XX/2025.
- 13.2 At the time of submission of the tender document, the Bidder shall give an undertaking that no changes have been made in document. The uploaded version of the Port Tender Document at <https://tender.nprocure.com> websites will be treated as authentic tender and if any discrepancy is noticed at any stage between the Port’s tender document and the one submitted by the Bidder, the conditions mentioned in the Port’s uploaded document on <https://tender.nprocure.com> websites shall prevail.
- 13.3 The employer may extend the deadline for submission of bids by issuing an amendment on DPA website as well as on <https://tender.nprocure.com> in which case all rights and obligations of the employer and the bidders previously subject to the original deadline will then be subject to the new deadline.
- 13.4 In case of tender documents being downloaded from the web site, at the time of submission of (the hard copy of) the tender document, the tenderer shall give an undertaking that no change have been made in document. Any discrepancy is noticed at any stage between the port’s tender document uploaded on <https://tender.nprocure.com> and the one submitted by the tenderer, the conditions mentioned in the port’s tender document uploaded on <https://tender.nprocure.com> shall prevail. Besides, the tenderer shall be liable for legal action for the lapses.

14. Late Bids

- 14.1 After the deadline of submission of bid, the bids cannot be submitted in the On-Line System.

15. Modification and Withdrawal of Bids

- 15.1 Bidders may modify or withdraw their bids before the deadline of submission of bid or extension if any.
- 15.2 No Bid can be modified after the last date for submission of Bids.
- 15.3 Withdrawal or modification of a Bid between the deadline for submission of bids and the expiration of the original period of bid validity including extension, if any, the bidder can be disqualified from bidding for any contract with DPA for a period of three years from the date of notification.

E. Bid Opening and Evaluation

16. Bid Opening

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

16.1 On the due date and time, the employer will first open Technical bids of all bids received including modifications.

16.2 In the event of the specified date for Bid opening being declared a holiday by the employer, the Bids will be opened at the appointed time on the next working day at the same time.

16.3 If any Bid contains any deviation from the Bid documents and / or if the same does not contain Bid security i.e., EMD and tender fees in the manner prescribed in the Bid documents, then that Bid will be rejected and the Bidder will be informed accordingly.

16.4 The bids which are technically qualified, their financial bids will be opened. The date of opening of financial bid will be declared in the <https://tender.nprocure.com> and www.deendayalport.gov.in as well as www.eprocure.gov.in.

16.5 The price bid i.e., BOQ will be opened only those bids qualify technically.

17. Clarification of Bids

17.1 To assist in the examination and comparison of Bids, the employer may, at his discretion, ask any Bidder for clarification of his Bid, including breakup of unit rates. The request for clarification and the response shall be in writing, but no change in the price of substance of the Bid shall be sought, offered, or permitted.

17.2 No Bidder shall contact the employer on any matter relating to his bid from the time of the bid opening to the time the contract is awarded.

17.3 Any effort by the Bidder to influence the employer’s bid evaluation, bid comparison or contract award decisions, may result in the rejection of his bid.

18. Examination of Bids and Determination of Responsiveness

18.1 Prior to detailed evaluation of Bids, the employer will determine whether each Bid

- (a) Has been properly digitally signed,
- (b) Meets the eligibility criteria defined
- (c) Is accompanied by the required Bid security and tender fees;
- (d) is responsive to the requirements of the Bidding documents.
- (e) GST to be quoted invariable by bidder.

18.2 A substantially responsive Technical and Financial Bid is one, which conforms to all the terms, conditions and specification of the Bidding documents.

18.3 If a Technical Bid is not substantially responsive, it will be rejected by the employer, and may not subsequently be made responsive by correction or withdrawal of the non-confirming deviation or reservation.

19. Evaluation and Comparison of Bids

19.1 The employer will evaluate and compare only the Bids determined to be responsive.

19.2 In evaluating the Bids, the employer will determine for each Bid the evaluated Bid

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

price by adjusting discounts, if any.

- 19.3 If in the opinion of Engineer In Charge, the rate quoted by successful bidder is abnormally high/low compared to the estimated cost of the work, the employer may ask the bidder to produce detailed price analysis for all items of the bill of quantities.

F. Award of Contract

20. Award Criteria

The employer will award the work to the bidder whose bid has been evaluated to be techno – commercially responsive and the lowest evaluated bid subject to submission of agreement and performance security.

21. Employer’s Right to accept any Bid and to reject any or all.

However prospective bidder(S) may raise query relating to bidding conditions, bidding process and/or rejection of its bids. The reasons for rejecting a tender or non-issuing tender to a prospective bidder will be disclosed where written enquiries are made by concerned bidder.

22. Letter of Award:

The Chief Mechanical Engineer will issue the Letter of Award (Form No.8) intimating the successful bidder about the proposed pre-acceptance of tender.

23. Notification of Award and Signing of Agreement

- i) The Bidder whose Bid has been accepted will be notified for the award by the employer prior to expiration of the Bid validity period by confirmation in writing. In this letter (hereinafter and in the Conditions of Contract called the “Letter of Award”) the contract amount, completion period of the work, etc will be mentioned in line with the tender conditions.
- ii) The notification of award will constitute the formation of the Contract subject to the furnishing of a performance security in accordance with the provisions of tender condition.
- iii) The Agreement will be submitted by successful Bidder within 14 days (National Bid) 28 days (Global Bid) of issue of the notification of award (Letter of Award). The agreement will incorporate all correspondence between the employer and the successful bidder.

24. Contract Agreement:

24.1 The agreement on stamp paper shall be furnished by the Contractor as per the following guidelines within 14 days (National Bid) /28 days (Global Bid) from the date of issue of Letter of Award.

- i) The successful Bidder will be required to execute an agreement at his expense on three Hundred Rupees (Rs.300/-) Non-Judicial Stamp Paper in the proper departmental format (Form 9) for the due and proper fulfilment of the contract within 14 days (national Bid) 28 days (Global bid) from the date of Letter of Award.

24.2 Pending preparation and execution of the contract agreement as above, the tender submitted by the Contractor together with Chief Mechanical Engineer’s letter/fax accepting the tender shall constitute a binding contract between the Board and the Contractor.

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

-
- 32.3. The contract period shall be reckoned from the date of issue of work order to commence the work.
- i) The original agreement as per the format attached with the tender should be executed on a stamp paper of appropriate value (at present Rs.300/-)
 - ii) The Agreement should be submitted in duplicate and the date of execution is to be kept blank.
 - iii) Each page of the document is to be signed by the Contractor/ his authorized representative by indicating his full name.
 - iv) If the Contractor is a partnership firm, then a copy of the Partnership Deed and in case it is a Company, a copy of Memorandum and Articles of Association along with Registration Certificate is to be submitted.
 - v) If the agreement is signed by a Partner/ a Director/ an authorized person of the firm, in such case, a certified true copy of the power of attorney/ letter of authority given by the firm/ company to the signatory of the Contractor firm is to be submitted.
 - vi) The entire agreement should be in type written form/ computer printed form.
 - vii) Leaving blanks and insertion of some contents of the agreement with hand writing should be avoided.
 - viii) All corrections/ additions made in the agreement are to be initialed.

25. Performance Security

Security deposit shall consist of two parts; a) Performance Guarantee to be submitted after issue of LOI, and b) Retention money to be recovered from Running Bills.

- 1) Performance Guarantee shall be 10% of the contract price, of which 5% of contract price should be submitted as Performance Guarantee in form of BG/FDR/Digital Transfer within 21 days, on receipt of Letter of Award and balance 5% to be recovered as Retention Money from Running Bills. Recovery of 5% Retention Money to commence from the First RA Bill onwards @ 5% of the Bill Value from each Bill. Retention Money will be refunded within 14 days from the date of payment of final bill. Balance SD will be refunded immediately not later than 14 days from completion of defect liability period.
- 2) Successful Bidder has to submit the Performance security @ 5% of Contract price within 21 days of receipt of Letter of Award, failing which the work will not be awarded and the Bid Security i.e., EMD will be forfeited.
- 3) The Deendayal Port Authority will also be at liberty to deduct from performance guarantee or from any sums of money due or that may become due under any contract with the contractor that may become due to the employer. This is without prejudice to the rights of the employer under the terms of the contract. The Bank Guarantee is required to be dispatched by the issuing bank directly to The Employer by Registered AD Post.
- 4) The Deendayal Port Authority may at their option forfeit the Performance Guarantee cum Security Deposit if the contractor fails to carry out the work or perform or observe the conditions of contract.
- 5) The bank guarantee towards performance guarantee cum security deposit will be accepted from any nationalized bank/scheduled bank (Except cooperative bank) having its branch at Gandhidham.”
- 6) The Performance Guarantee cum Security Deposit will be released after successful completion

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

of guarantee period.

- 7) BG submitted by the contractor should remain valid for a period of 60 (Sixty) days beyond the date of completion of all contractual obligations of the concerned contractor including Defect Liability Period
- 8) The documentary evidence (copy of paid challan in government treasury) of welfare cess @1% of work done or as amended by statutory authority from time to time, paid on final bill shall be submitted before releasing the performance guarantee.

26. Issue of Work Order

Work order will be issued indicating the Contract value, completion period etc. after submission of Performance Security Deposit and Contract Agreement on Non-Judicial Stamp Paper by the successful bidder as per Tender Conditions.

27. Time Schedule

The Contract shall be effective from the date of issue of Work Order and the work shall be completed within Three (03) months from the date of issue of Work Order.

28. Corrupt or Fraudulent Practices

28.1 The employer requires that Bidders/Suppliers/Contractors under this contract, observe the highest standard of ethics during the procurement and execution of this contract. In pursuance of this policy, the employer:

- (a) defines the following for the purpose of these provisions :
 - (i) “Corrupt practice” means the offering, giving, receiving or soliciting of anything of value to influence the action of a public official in the procurement process or in contract execution; and
 - (ii) “fraudulent practice” means a misrepresentation of facts in order to influence a procurement process or the execution of a contract to the detriment of the employer, and includes collusive practice among Bidders (prior to or after bid submission) designed to establish bid prices at artificial non-competitive levels and to deprive the employer of the benefits of free and open competition.
- (b) Will reject a proposal for award of work if he determines that the Bidder recommended for award has engaged in corrupt or fraudulent practices in competing for the contract in question.
- (c) will declare a Bidder ineligible, either indefinitely for a stated period of time, to be award ea a contract/contracts if he at any time determines that the Bidder has engaged in corrupt or fraudulent practices in competing for or in executing, the contract.

(d)

**Signature & Seal
Of Contractor**

**Executive Engineer (E)
Deendayal Port Authority**

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

SECTION – II

GENERAL CONDITIONS OF CONTRACT

GENERAL CONDITIONS

1. Definitions

In the Contract (as hereinafter defined) the definition of the following words and expressions shall have the meanings hereby assigned to them except where the context otherwise requires:

- a. **“Employer”** means Board of Deendayal Port Authority, a body corporate under the Major Port Authorities Act.2021, by notification issued by the Government of India, acting through its Chairman, Dy. Chairman or Chief Mechanical Engineer or any other officers so nominated by the Board.
- b. **“Contractor”** means the person or persons, firm, corporation or company whose tender has been accepted by the employer and includes the Contractor’s servants, agents and workers, personal representatives, successors and permitted assigns.
- c. **“Contract”** means and includes Tender Documents, Instructions to Bidders, General Conditions of Contract, Drawings, Specifications, and Schedules etc., any amendments thereto, Bid, Letter of Award, Contract Agreement and the work order.
- d. **“Contract Price”** means the total sum of money to be paid by the employer to the contractor on timely completion of the contract work as per Contract including payment for extra work, i.e. as per defined and applicable items of the terms of payment, including any taxes and excise duties to be paid to state or central Government.
- e. **“Specifications”** means the specification referred to in the tender documents and any modifications thereof or additions thereto or amendments thereto as may be from time to time be furnished or approved in writing by the employer.
- f. **“Chief Mechanical Engineer”** shall mean the Chief Mechanical Engineer of Deendayal Port Authority.
- g. **“Work” or “Works”** shall mean the whole of the plant and materials to be provided and work to be done executed or carried out by the contractor under the contract.
- h. The **“Site”** shall mean the whole of the premises, buildings and grounds in or upon which the system or works is or are to be provided, executed, erected, done or carried out.
- i. The **“Schedule”** shall mean the schedule or Schedules attached to the specifications.

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

- j. The **“Drawings”** shall mean the drawings, issued with the specification which will ordinarily be identified by being signed by the Chief Mechanical Engineer and any further drawing submitted by the contractor with his tender and duly signed by him and accepted or approved by the Chief Mechanical Engineer and all other drawings supplied or furnished by the contractors or by the Chief Mechanical Engineer in accordance with these contract conditions.
- k. **“Trials” and “Tests”** shall mean such trials and tests as are provided for in these conditions of contract and described in the specification and shall include all other tests to be carried out as per the requirement of the ‘employer’.
- l. **“Approved” or “Approval”** shall mean approval in writing.
- m. **“Engineer-in-charge/Nodal officer”** shall mean any officer/Engineer authorized by Chief Mechanical Engineer for purpose of this contract.
- n. **“Day”** re calendar days, **“months”** are calendar months
- o. **“Equipment”** is the contractor’s machinery and vehicles brought temporarily to the site to construct the works.
- p. **“Material”** are all supplies, including consumables, used by the contractor for incorporation in the works.
- q. **“Plant”** is any integral part of the works, which is to have mechanical, electrical, electronic, chemical, or biological function.

2. Use of Contract Document:

The Contractor shall not, without prior consent, make use of any document except for the purpose of performing this contract.

3. Change Orders :

At any time during the execution of the contract, by a written notice to the Contractor, changes may be made in the general scope of contract. The Engineer In-charge (EIC), with due approval of competent authority, may make any changes in the quality and/or quantity of the work or any part thereof that may, in his opinion, be necessary and for that purpose the Engineer In-charge shall have the power to order the Contractor to do and the Contractor shall do any of the following:

- a. Increase or decrease or split the quantity of work included in the contract,
- b. Omit any such work,
- c. Change the character, quality or kind of any such work,
- d. Change the dimensions of any such work,
- e. Change in Location

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

f. Execute additional work of any kind necessary for completion of the work under the contract, and no such change shall in any way vitiate or invalidate the contract but the cost, if any, arising out of all such changes shall be taken into account in ascertaining the total amount of the contract price. Where the rate is available in the contract and the same is applicable to the additional work, in the opinion of the EIC, the cost of the additional work shall be determined as per this available rate. But, if the rate for additional work is not available in the contract, the same shall be determined by the EIC taking into account the market rate and labour cost at the site for similar works and shall be final.

g. Deviations from the specifications as contained in the tender agreement including the make / model, shall not be accepted. In case of any such deviation, payment shall not be made for that part of the work / item, even if it is meeting the functional requirements and has been accepted by the purchaser. The payment for such portion of the work / item can only be released if the contractor makes good the deviations before the expiry of the warranty period so as to meet the specifications of the tender agreement in all respects.

4. Resolution of Dispute

a) The Board and the Contractor shall make every effort to resolve amicably by direct informal negotiations, any disagreement or dispute arising between them in connection with the contract. However, in case of failure of negotiation between the Board and the Contractor, the parties shall refer their present and future disputes relating to the contract itself or arising out of or concerning or in connection with or in consequence of the contract to the Chairman, DPA whose decision shall be final and binding on both the parties. The contract shall be governed by the Indian Contract Act, 1872.

b) Jurisdiction of Courts:

All such disputes, which could not be settled at the intervention of Chairman, DPA, shall be subjected to the jurisdiction of the courts at Gandhidham.

5. Force Majeure:

5.1 In the event that the Contractor is delayed in performing its obligations in the contract, and such delay is caused by force majeure including war, civil resurrection, strikes (other than the strike solely by the Contractor’s men), fire, flood, epidemics, earthquakes, extremely adverse climatic conditions, such delay may be excused and the period of such delay may be added to the time of performance of the obligations without any addition to the contract price.

5.2 If a force majeure situation arises, the Contractor shall promptly notify the Board in writing of such condition and the cause thereof, **but not later than 7 days from its occurrence**. Unless otherwise directed by the Board in writing, the Contractor shall continue to perform its obligations under the contract as far as reasonably practicable. The Contractor shall demonstrate to the Board’s satisfaction that it has used its best endeavor to avoid or overcome such causes of delay

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

and the parties will mutually agree upon remedies to mitigate or overcome such causes of delay without having any right to any claim on account of such force majeure.

5.3 In any other situation, which is beyond the reasonable control of the Contractor in the opinion of the Engineer In-charge, and where the Contractor has promptly notified the Board in writing about such situation, it may be considered as “Force Majeure” situation.

6. Compliance with Statutes, Regulations:

The Contractor shall comply in all respects, with all statutes and regulations as may be necessary, including clearance from State/Central Govt. authorities, Pollution Control Boards, labour enforcement and local authorities. The Contractor shall, at all times during the continuance of the contract, so far as it may be necessary, comply with all the existing enactments including Central and State legislation as well as any by-laws of any local authorities regarding labour, particularly the Minimum wages Act, Factories Act, Workmen’s Compensation Act, Employees’ Provident Fund and Family Pension Fund Act, Employees’ State Insurance Act, Contract Labour (Regulation and Abolition) Act, Payment of Wages Act, Maternity Benefit Act, National and Festival Holidays Act, Shop and Establishment Act, The Apprentice Act and keep DPA indemnified against any loss or claim arising out of contravention of the provisions of the above said enactments by the Contractor. The price quoted by the Contractor in the Bill of Quantity shall be deemed to include all expenses whatsoever the Contractor may be required to incur for the compliance with the provisions of the above said legislation. The Contractor shall make necessary arrangements for DPA to witness the payment made by the Contractor to his staff and labour.

7. Payment Terms:

(This clause is superseded by Clause No. 2 under Special Conditions, Section-III)

All payments shall be made in Indian rupees unless specifically mentioned.

(I) In respect of tender for supply and installation (Changes to be made as per nature of the Work)

- i. 70% of above item rate against receipt of material at site in good condition after obtaining insurance cover as per tender condition (if TPI appointed then after inspection & certification of the same by Third Party Inspection Agency).
- ii. 20% of item rate after completion of erection, installation, testing and commissioning, etc. (if TPI appointed then after inspection & certification of the same by Third Party Inspection Agency) and 90% of item rate for item covers only supply/laying/fixing (if any).
- iii. 10% will be released after successful completion of whole work (if TPI appointed then after inspection & certification of the same by Third Party Inspection Agency).

II) In respect of lump sum work (Changes to be made as per nature of the Work)

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

8.5 During erection and till the work is completed and satisfactory taken over by the D.P.T after testing the materials shall stand covered by suitable erection insurance also for the value of 110% of the item. The charges for the insurance shall be borne by the Contractor.

9. Time Extensions:

The Contractor may claim extension of the time limits in case of;

- i) Changes ordered by Deendayal Port Authority.
- ii) In case work is delayed on DPA’s Account, i.e. due to delay in approval of drawings, non-availability of site clearance or any other reason, DPA will consider time extension of merit. However, no compensation will be paid to the Contractor if work is delayed on DPA’s account. The Contractor shall submit the request for extension, within 30 days of occurrence of such delay, clearly indicating the justification for such extension.
- iii) Force Majeure.
- iv) All the incidents of delay should be entered in the hindrance register which will be base for granting any extension.

10. Time is the essence of the contract:

Time is the essence of the contract and the Contractor shall ensure that all the obligations under the contract are completed within the agreed time schedule. The Contractor shall be solely responsible for all the delays including the delays caused by it’s vendors. In case of delay in progress of the works, Deendayal Port Authority reserves the right to withhold the payment, cancel the contract unilaterally or complete the work departmentally.

11. Liquidated Damages:

11.1 In case of delay in completing the contract, liquidated damages (LD) may be levied at the rate ½% of the contract value per week of delay or part thereof subject to a maximum of 10% of the contract price.

11.2 The employer, if satisfied that the works can be completed by the contractor within a reasonable time after the specified time for completion may allow further extension of time at its discretion with or without the levy of LD. In the event of extension of time at its discretion with LD the employer will be entitled without prejudice to any other right or remedy available in that be half percent (½%) of the contract value of the works for each week or part of the week subject to the ceiling 10% of contract value.

11.3 The employer, if not satisfied that the works can be completed by the contract, and in the event of failure on the part of the contractor to complete work within further extension of time allowed as aforesaid shall be entitled without prejudice to any other right or remedy available in that behalf to rescind the contract.

11.4 The employer, if not satisfied with the progress of the contract and in the event of failure of the contract to recoup the delays in the mutually agreed time frame, shall be entitled to terminate the contract.

11.5 In the event of such termination of the contract as described in clauses (11.3) or (11.4) or both, the employer shall be entitled to recover LD upto ten percent (10%) of the contract value and forfeit the security deposit made by the contract besides getting the work completed by other means at the risk and cost of the contractor.

11.6 In case part/portion of the work can be commissioned and port operates the portion for commercial purpose, the rate of LD will be restricted to the uncompleted value of work, the maximum

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

LD being on the entire contract value.

12. Variations:

12.1 Variation in Conditions of Contract:

In case of any variation in Instructions to Bidders (ITB), General Conditions of Contract (GCC) and the Special Conditions of Contract – if any special conditions of contract shall prevail. But in case of any requirement/condition specified in the Scope of Work, it shall prevail over all other conditions.

12.2 Variation in Quantities of Schedule – B:

The overall as well as individual variations shall be $\pm 30\%$ in quantity for which the rate quoted by the bidder and accepted by the employer shall be applicable.

13. Acceptance:

Upon completion of work under this contract, the Board may accept the works and/or services after installation, if defects or shortcomings are not considered essential and, the Contractor agrees to make good the deficiencies in confirmation with this contract. No work shall be accepted before the Contractor clears the site of scraps, unused materials, work shed, equipment and all such materials which were used for execution of the work and not required any more at the worksite. Also, the Contractor has to submit all the documents and final “as built” drawings as per the contract agreement without which no work shall be treated as complete.

Completion Certificate shall be issued by the employer after satisfactory completion of work as per tender and after taking trial.

14. Guarantee:

(This clause is superseded by Clause No. 4 under Special Conditions, Section-III)

14.1 The warranty period shall be valid up to six/twelve months (6 months for repairs and 12 months for new works including supplied items) with effect from the date of acceptance of the work and/or services, unless otherwise specified in the scope of work/Special Conditions of Contract (SCC).

14.2 The Contractor shall warrant the Board that the goods and services under this contract will comply strictly with the contract, shall be first class in every particular case and, shall be free from defects. The Contractor shall further warrant the Board that all materials, equipment and the supplies furnished by him will be new and fit for their intended purposes.

14.3 The Board shall promptly notify the Contractor in writing of any claim arising under this Warranty. Upon receipt of such notice, the Contractor shall promptly repair or replace the defective goods and/or services at no cost to the Board.

14.4 If the Contractor, having been notified, fails to rectify the defects in accordance with the contract, the Board may proceed to take such remedial action as may be necessary, at the Contractor’s risk and cost.

15 Taxes:

GST Clause:

The contractor shall quote the price exclusive of GST. The contractor shall quote prevailing GST rate separately, which shall be reimburse by DPA after ascertaining necessary compliance as per Goods & Service Tax, 2017.

All other duties, taxes, cesses applicable if any, shall be borne by the contractor.

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

Deduction of Income-Tax:

Income-Tax deductions and surcharge as applicable thereon shall be made good while making payments due to the contractor for carrying out the work and only net amount shall be paid as directed by the Central Board of Direct Taxes, Ministry of Finance, Government of India.

Tax: The rates quoted by the contractor shall be deemed to be inclusive of the taxes, duties etc. which the contractor will have to pay for the performance of this contract. The employer will perform such duties in regard to the deduction of such taxes at sources as per applicable law.

16. Deduction:

16.1 Deduction of taxes/income tax at source shall be made from the any bill of the Contractor in accordance with the prevailing rules of Govt.

16.2 While performing under the contract, the damages caused by the Contractor or his workersto any of the Port Authority property shall be promptly made good by the Contractor at his own cost. In case the Contractor fails to repair/replace the damage, Deendayal Port Authority shall have the right to take steps to make good the damages and all the cost on this account shall be recovered from the bills of the Contractor or any money due to the Contractor from this contract or any other contract or any other transaction. In determination of the damage, the opinion of the Engineer-In-charge (EIC) shall be conclusive.

16.3 Any dues arising out of failure on the part of the Contractor to carry out any obligation under the contract shall be deducted from the bills of the Contractor or from any money due to the Contractor from this contract or any other contract.

17. Subcontracts:

The Contractor shall not be allowed to engage any sub-contract for all or any part of this contract.

18. Idle Charges:

All efforts shall be made for timely supply of materials and/or equipment where it is included in the scope of Deendayal Port. However, the Contractor shall not be entitled to any idle charges for delay in supply of materials and/or equipment by the Port Authority. Further, in case of any delay due to stoppage of work ordered by the Port Authority to avoid interruption in other important activities of Port Authority or any other reason, the Contractor shall not claim any idle charges.

19. Personal Protective Equipment: (PPE)

The Contractor shall be solely responsible, at his own cost, for the supply of required PPE to his workers and staff and he shall also ensure the use of PPE such as helmets, nose masks, hand gloves etc. by his staff at site.

20. Conduct:

The Contractor, at all times during the tenure of contract, shall take all measures to prevent any unlawful, riotous or disorderly conduct by or amongst his staff at the site and for the preservation of peace and protection of persons and property at the work site as well as in the enactment of the works.

21. Accident:

The Contractor shall, within 24 hours of the occurrence of any accident, at or about the work site or in connection with execution of the contract, report such accidents to the Engineer-In-Charge giving

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

all the details in writing. He shall also provide additional information about the accident as requested by the EIC.

22. Watch and ward:

During the execution of the contract, it shall be the responsibility of the Contractor to arrange watch and ward of the work including the raw materials, machine/equipment/system used for the work at his own cost till the date of acceptance of the work by Deendayal Port Authority.

23. Termination:

23.1 The Board may, without any prejudice to any other remedy for breach of contract, by written notice of default sent to the Contractor, terminate the contract in whole or in part:

(i) if the Contractor fails to execute the work within the period as specified in the contract or any extension granted by the Board;

(ii) if the Contractor fails to perform any other obligation under the contract and if the contractor does not cure the same after receipt of a notice of default, the nature of default as well as the time within which the default has to be cured by the Contractor.

23.2 In the event of Board’s termination of the contract in whole or in part, the Board may execute the remaining work or procure goods similar to those undelivered by the Contractor and the Contractor shall remain liable to the Board for any excess cost for such works or goods and risks, if any.

23.3 The Board will pay the Contractor, for all the items that are completed and ready for delivery, within 30 days after termination. The payment shall be made only after all the afore-mentioned goods are supplied to and accepted by Deendayal Port Authority. The amount so decided by the Engineer-in-Charge in this regard shall be final and binding.

23.4 In case of termination of contract for default by the Contractor, the Board may not permit the Contractor to participate in any of the future tender of Deendayal Port Authority for a period decided by DPA.

23.5 The employer may terminate the contract if Contractor causes a fundamental breach of the contract.

23.6 Fundamental breaches of contract include, but shall not be limited to the following:

a) The contractor stops work for 28 days and the stoppage has not been authorized by the Engineer-in-Charge or his nominee.

b) The contractor becomes bankrupt.

c) The contractor has delayed the completion of works by the number of days for which the maximum amount of liquidated damages can be paid as defined in the contract data and

d) If the contractor, in the judgment of the employer has engaged in corrupt or fraudulent practices in competing for or in the executing the contract.

e) For the purpose of this paragraph: “corrupt practice” means the offering, giving receiving or soliciting of anything of value to influence the action or public officials in the procurement process or in contract execution. “Fraudulent practice” means a misrepresentation of facts in order to influence a procurement process or the execution of a contract to the detriment of the employer, and includes collusive practice. Bidders (prior to or after bid submission) designed to establish bid prices at artificial non-competitive levels and to deprive the employer of the benefits of free and open competition”.

f) If the contract is terminated the Contractor shall stop work immediately, make the site safe and secure and leave the site as soon as reasonably possible.

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

g) Any material lying at site will not be removed without the prior written permission of Engineer In Charge.

24. Arbitration Clause:

(I) Except where otherwise provided in the contract, all questions and disputes relating to the meaning of the specifications, designs, drawings and instructions herein before mentioned and as to the quality of workmanship or materials used on the work or as to any other question, claim, right, matter or any other thing whatsoever, in any way arising out of or relating to the contract, designs, drawings, specifications, estimates, instructions, orders, or to the conditions or otherwise concerning the work or regarding the execution or failure to execute the same whether arising during the progress of the work or after the completion thereof as described hereinafter shall be referred to the Chairman for sole arbitration by himself or by any officer appointed by him.

(II) It will be no objection to any such appointment that the arbitrator is an employee of the Board or the Government, that he had to deal with the matters to which the contract relates and that in the course of his duties as an employee of the Board of the Government, he had expressed views on all or any of the matters in dispute or of difference.

The arbitrator, who has been dealing with the arbitration case, being transferred or vacating his office or in the event of his death or being unable to act for any reason, the Chairman then holding the office shall arbitrate himself or appoint any officer to act as arbitrator.

(III) It is also a term of this contract that no person other than the Chairman himself or any officer appointed by him shall act as arbitrator.

(IV) It is a term of this contract that only such questions and disputes as were raised during the progress of other work till its completion and not thereafter shall be referred to arbitration. However, this would not apply to the questions and disputes relating to liabilities of the parties during the guarantee period after completion of the work.

(V) It is a term of the contract that the party invoking arbitration shall give a list of disputes with amount of claim in respect of each said disputes along with the notice seeking appointment of arbitrator.

(VI) It is also a term of the contract that if the Contractor does not make any demand for appointment of arbitrator in respect of any claims/disputes in writing, as aforesaid, within 120 days of receiving the intimation from the Engineer –in-charge that the final bill is ready for payment, the claim of the Contractor shall be deemed to have been waived and absolutely barred and the Port Authority shall be discharged and released of all liabilities under the contract in respect of these claims.

(VII) It is also a term of the contract that the arbitrator shall adjudicate only such disputes/claims as referred to him by the appointing authority and give separate award against each dispute/claim referred to him. The arbitrator will be bound to give claim wise detail and speaking award and it should be supported by reasoning.

(VIII) The award of the arbitrator shall be final, conclusive and binding on all the parties to Contractor.

(IX) The arbitrators from time to time, with the consent of both the parties, enlarge the time for making & publishing the award.

(X) Arbitration shall be conducted in accordance with the provisions of Indian Arbitration Act, 1996 or any statutory modifications or enactment thereof and rules made there under and for the time being in force shall apply to the arbitration proceeding under this clause.

(XI) It is also a term of the contract that if any fees are payable to the arbitrator, this shall be

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

ped equally by both the parties.

(XII) It is also a term of a contract that the arbitration shall be deemed to have been entered on the reference on the date he issues the first notice to both the parties calling them to submit their statement of claims and counter statement of claims.

(XIII) Venue of the arbitration shall be such place as may be fixed by the arbitrator at his sole discretion.

25. Indemnification:

The Contractor shall indemnify, protect and defend at its own cost, Deendayal Port Authority and its agents & employees from & against any/all actions, claims, losses or damages arising out of

- a. any violation by the Contractor in course of its execution of the contract of any legal provisions or any right of third parties;
- b. Contractor’s failure to exercise the skill and care required for satisfactory execution of the contract.

26. Engineer-in-Charge or his nominee’s Decisions

Except where otherwise specifically stated, the Engineer-in-Charge or his nominee will decide contractual matters between the employer and the Contractor in the role representing the employer.

27. Delegation

The Engineer-in-Charge may delegate any of the duties and responsibilities to other Officers / officials after notifying the Contractor and may cancel any delegation after notifying the Contractor.

28. Communications

Communications between parties which are referred to in the conditions are effective only when in writing. A notice shall be effective only when it is delivered (in terms of Indian Contract Act 1872).

29. Personnel:

29.1 The Contractor shall employ the key personnel named in the Schedule of Key Personnel as referred to in the Contract Data to carry out the functions stated in the Schedule or other personnel approved by the Engineer-in-Charge. The Engineer-in-Charge will approve any proposed replacement of Key personnel only if their qualifications, abilities, and relevant experience are substantially equal or better than those of the personnel listed in the Schedule.

29.2 If the Engineer-in-Charge asks the Contractor to remove a person who is a member of the Contractor’s staff of his work force stating the reasons, the Contractor shall ensure that the person leaves the Site within seven days and has no further connections with the work in the Contract.

30. Employer’s Obligation

(This clause is superseded by Clause No. 5 under Special Conditions, Section-III)

- (i) Electricity and water execution of the work at site shall be provided on Free of cost subject to availability. Necessary arrangements has to be borne by contractor.
- (ii) The employer will not provide accommodation, during the tenure of contract. However, suitable accommodation will be provided for site office purpose at inside cargo jetty area.
- (iii) Administrative support only, for obtaining clearance from any statutory authority, shall be provided by the employer.

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

(iv) On successful completion of all the obligations under the contract and on the request of the Contractor, the employer shall issue a “Completion Certificate with the approval of the Chief Mechanical Engineer, the employer.

31. Queries about the Technical Data

The Engineer-in-Charge will clarify queries on the Technical Data.

32. Approval by the Engineer-in-Charge.

The Contractor shall submit the make of material, equipment’s, specifications and drawings for proposed Work to the Engineer-in-Charge, who is to approve them subject to compliance with the Technical specifications and drawings.

The Engineer-in-Charge approval shall not alter the Contractor’s responsibility for the work.

All drawings prepared by the contractor for the work if any, are subject to prior approval by the Engineer In Charge or his nominee before procurement/execution

33. Discoveries

Anything of historical or other interest or of significant value unexpectedly discovered on the site is the property of the employer. The contractor is to notify the employer or his nominee of such discoveries and carry out the instructions of employer or his nominee for dealing with them.

34. Access to the site

The contractor shall allow the Engineer in charge or his nominee and any person authorised by him access to the site to any place where work in connection with the contract is being carried out or is intended to be carried out and to any place where materials or plant are being manufactured, fabricated and/or assembled for the work.

35. Instructions

The contractor shall carry out all instructions of the engineer or his nominee which comply with applicable laws where the site is located.

36. Safety

The Contractor shall be responsible for the safety of all activities on the Site.

Quality Control

37. Identification of Defects

The Engineer-in-Charge or his nominee shall check the work carried out by Contractor and notify the Defects found if any. The Engineer-in-Charge or his nominee may instruct the Contractor to rectify the Defect.

38. Correction of Defects

38.1 The Engineer-in-Charge or his nominee shall give notice to the Contractor of any Defects before the end of the Defects Liability Period (Guarantee Period), which begins at Completion and is defined in the Contract Data. The Defects Liability Period shall be extended for as long as Defects remain to be corrected.

38.2 Every time notice of a Defect is given the Contractor shall correct the notified Defect within the length of time specified by the Engineer-in-Charge or his nominee’s notice.

39. Uncorrected Defects

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

If the Contractor has not corrected a Defect within the time specified, the Engineer-in-Charge or his nominee will assess the cost of having the Defect corrected, and the Contractor will pay this amount.

40. Employer’s right of Rejection:

The employer shall reserve the right to reject a part portion or consignment thereof within a reasonable time after actual delivery thereof at the place of destination, if consignment is not in all respects in conformity with terms & conditions of the contract whether on account of any loss, deterioration or damage before dispatch or delivery or during transit or otherwise whatsoever.

41. Removal of Rejected goods:

Rejected goods shall under all circumstances lay at the risk of the contractor from the moment of rejection and if such goods are not removed by the contractor within 21 days from the date of intimation from the Engineer-in-Charge. Engineer-in-Charge may either return to the contractor at the risk and cost of the contractor by such mode of transport as the Engineer-in-Charge may selector dispose off such material at the contractor’s risk on his account and retain such portion of the sale proceeds as may be necessary to recover any expenses incurred in such disposals.

42. Use of Contract Document:

The Contractor shall not, without prior consent, make use of any document except for the purpose of performing this contract.

43. Memorandum of Settlement:

The Contractor shall not sign any memorandum of settlement with any agency such as Trade Unions etc. in any form at any level without the prior written permission of the employer in relation to any work under taken by him in the Port premises.

44. Deviations:

The bidder must read the tender document carefully and prepare the bid for submission. It is important to note that deviations, if any, must be brought out clearly in the technical offer, which shall be examined by Deendayal Port Authority. If the deviation statement submitted by the bidder does not contain any item, then it shall be construed that the bidder has accepted the same and no request from the Contractor, for any change, shall be accepted by DPA at a later stage. In any case, no change in specifications given in the tender agreement shall be permitted. However, only in unavoidable circumstances, Deendayal Port Authority may consider such requests from the Contractor, provided the Contractor submits it’s request with adequate justification.

45. Approvals:

The Engineer-in-Charge shall give specific approval in writing within 7 Days to Contractor after written submission regarding Makes of Material to be used for the Contract and Drawings, if any to be furnished by the Contractor to Engineer-in-Charge for approval. Any corrections to be suggested by Engineer-in-Charge in drawings, the days taken for rectification in drawings shall be in account of the Contractor.

46. Third Party Inspection:

(This clause is superseded by Clause No. 6 under Special Conditions, Section-III)

i. The Third Party Inspection Agency shall be arranged by DPA and cost of Third Party Inspection mentioned below shall be borne by DPA.

ii. The Third Party Inspection Agency will carry out approval of drawings if any, material inspection at manufacturer’s works/site, dispatch clearance from manufacturer’s work, certification for releasing stage payments as per payment terms of contract for all the materials as per schedule/work till

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

taken over by DPA.

iii. The Third Party shall carry out inspection of work as per tender specification/relevant standard.

iv. The above stage payment shall be released after certifying by the third party and copy of the same shall be produced by Contractor for releasing the stage payment as per **Payment Terms**.

47. Bar Chart

The Contractor shall submit a bar chart, before signing the agreement, clearly indicating the plan for timely execution of the work. The bar chart must indicate the individual activities and commencement and completion dates of each activity. The bar chart shall be used for monitoring the progress of the work

48. Engagement of Labour:

The contractor shall, unless otherwise provided in the Contract, make his own arrangements for the engagement of all staff and labour, local or other, and for their payment, housing, feeding and transport.

49. Police verification of contract labour

The Contractor who has been awarded the job through Work Order shall furnish necessary Police Clearance Certificate in respect of character and antecedents of all Contract Labourers engaged by them, before commencing the work at site.

This will be a part of Contractual Agreement, as entire Cargo Jetty, Oil Jetty area has been declared as “**Prohibited Area**”. Contractor who would be awarded contract is required to comply with the above requirements.

Contractor shall obtain such Police Clearance Certificate from Police available against a nominal fee per Certificate and they will submit this Certificate giving Work Order reference on it, to the Office of the Engineer In Charge of respective Divisions, to be forwarded to Commandant, CISF which our Security Department along with request for issuance of Entry Passes.

The Contractor shall, if required by the Engineer-in-Charge, deliver to the Engineer-in-Charge a return in detail, in such form and at such intervals as the Engineer-in-Charge may prescribe, showing the staff and numbers of the several classes of labour from time to time employed by the Contractor on the Site and such other information as the Engineer-in-Charge may require.

a) Submission of Labour Reports by Every Fortnight:

The contractor shall submit, by the 4th and 19th of every month, to the Engineer-in-Charge a true statement showing, in respect of the second half of the preceding month and the first half of the current month respectively.

1. The number of labourers employed by him on the work.
2. Their working hours.
3. The wages paid to them.
4. The accidents that occurred during the said fortnight showing the circumstances under which they happened and the extent of damage and injury caused by them, and
5. The number of female workers who have been allowed Maternity Benefit, according to clause 19 F and the amount paid to them, failing which, the Contractor shall be liable to pay to

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

Government a sum not exceeding Rs. 200/- for each default or materially incorrect statement. The decision of the Engineer-in-Charge shall be final in deducting from any bill due to the contractor the amount levied as fine and be binding on the contractor.

b) No Labour Below 14 Years:

No labour below the age of 14 (fourteen) years shall be employed on the work.

50. Registers to be maintained at site:

1. Site order Book:

A site order book is to be maintained by the contractor at the site. The work orders and instructions written in the site order book shall be deemed to have been legally issued to the contractor shall sign each entry in the site order book as a token of his having seen the same. The site order book shall be property of the Board and shall be handed over to the Engineer-in-charge of the work in good condition on the completion of the work or whenever required by the Engineer-in-charge or his authorized representative

2. Hindrance Register

Every type of hindrance arising during the execution of work should be invariably recorded in the hindrance register. The Hindrance Register is to be maintained by the Engineer in Charge at the site. The contractor shall sign each entry in the hindrance Register as a token of his having seen the same. The Hindrance Register shall be property of the Board.

51. No damage, hindrance or interference to the Port activities:

The contractor shall be required to execute the work in such a manner as not to cause any damage, hindrance or interference to the Port activities and the work going on in the area. The contractor shall have to make good the loss at his own cost and risk all damages caused by his workmen to Port property and no extra payment shall be made to him on that account.

52. Tools & Tackles:

All the tools, tackles, ladders etc. for executing the work will have to be arranged by the contractor at his own cost. Arrangement for storing the materials, tools etc. will also have to be made by him. The EMPLOYER shall not be responsible for any theft/loss of any materials, tools, etc. stored/brought by the contractor for execution of work within the Port area.

53. Hot work:

In case of carrying out any hot work such as gas cutting and welding necessary regulations, prevailing at Deendayal Port Authority for such works shall be observed by the tenderer and necessary fire watch permit and No Objection Certificate shall be provided by DPA free of cost obtained from the concerned authorities of the port.

54. Indian Dock Safety Regulations:

Necessary Indian Dock Safety Regulations for the safety purpose shall be adhered to by the contractor and he will be held responsible for any violation of the same.

55. Valid Electrical Contractor License and Electrical Supervisor Certificate:

(This clause is superseded by Clause No. 7 under Special Conditions, Section-III)

The contractor shall have valid electrical contractor’s license for carrying out electrical work of nature involved in this tender obtained from the Commissioner of Electricity, Energy & Petrochemical Department, (Inspection wing), Block No.18, 6th floor, Sector No.II, Udyog Bhavan, Gandhinagar,

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

Government of Gujarat without which the tender shall not be accepted. Contractor shall submit certificate and copy of the license in lieu of the same for consideration.

The contractor shall engage a person having valid Electrical Supervisor’s certificate of competency, issued from the Commissioner of Electricity, Energy & Petrochemical Department, (Inspection wing), Block No.18, 6th floor, Sector No.II, Udyog Bhavan, Gandhinagar, Government of Gujarat or equivalent authority from the other states/central Govt, under whose supervision electrical work will be carried out.

56. Action where no Specifications are specified:

The work shall be carried out in all respects in accordance with the instructions and requirements of the Engineer-in- Charge.

57. Undertaking by the Contractor:

Having understood all the terms and conditions of the tender document and having assessed the site conditions, we hereby confirm that the price offered by us is a firm price and includes all the taxes (excluding service tax), duties, fees, Cess etc. and all incidental charges.

58. Labour License:

The contractor will have to obtain License from Assistant Labour Commissioner (ALC), Goplapuri, Gandhidham (Kutch), in case he is engaging ten or more workers on any day during execution of work.

59. Fraudulent documentation by bidders:

Submission of fraudulent documents shall be treated as major violation of the tender procedure and in case the port shall resort to forfeiture of EMD (of any) / SD/BG of the bidder, apart from blacklisting the firm for the next 3 years.

60. The contractor shall be registered under the Building and Other Construction Workers (Regulation of Employment and Conditions of Service) Act, 1996.

-Sd/-

**Signature & Seal
of Contractor**

**Executive Engineer (E)
Deendayal Port Authority**

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

SECTION -III

SPECIAL CONDITIONS

(These special conditions will supersede the General Condition and ITB wherever applicable.)

1. Clause No. 6 of Instructions to Bidders (ITB), Section-I is not applicable.
2. The Clause No. 7 of General Condition of Contract (GCC), Section-II is modified and shall be read as under:

Payment Terms:

All payments shall be made in Indian rupees unless specifically mentioned.

- i. **Payment shall be release of 70% of Supply** item rate against receipt of material at site in good condition after obtaining insurance cover as per tender condition and after inspection & acceptance of material by DPA & Certification by Third Party Inspection Agency (TPIA).
- ii. 20% of supply item rate after completion of erection, installation, testing and commissioning, etc. and 90% of item rate for item covers only laying/fixing/ erection & commission etc. & certification by Third Party Inspection Agency (TPIA).
- iii. 10% will be released after successful completion of whole work and handing over to DPA & certification by TPIA.

NOTE:

The payment shall be made through RTGS /NEFT and the Contractor should be furnished following details: -

Bank Payment Agreement Form

- a. Name of Party
- b. Account No.
- a. Branch Name
- b. Branch Station
- c. IFSC code of the bank
- d. MICR co
- e. Accepted for:- NEFT payment or RTGS payment

Declaration by the party

I/We hereby declare that the above information furnished by me is correct and DPA is requested to pay my / our dues to this account for this work is concerned.

Signature of the party with the seal

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

Declaration by the bank

It is hereby informed that the details mentioned by the party is correct as per our records and any payment made by DPA to this account will be accepted either by RTGS/NEFT.

Signature of the bank manager with the seal.

3. **The Clause No. 8 of General Condition of Contract (GCC), Section-II is modified and shall be read as under:**

Insurance:

3.1 The contract shall provide in the joint names of the employer and the contractor, insurance cover from the start date to the end of guarantee period for the following events which are due to the contractor risk:

- a) loss of or damage to the works, plan and materials
- b) loss of or damage to equipment
- c) loss of or damage of property (except the works, plant, materials and equipment) in connection with contract, and
- d) personal injury or death.

3.2 All the materials shall stand insured from the time of arrival at site till commencement of erection against fire, pilferage, damage and against natural calamities for the value of 90% of each item.

3.3 During erection and till the work is completed and satisfactory taken over by the DPA after testing the materials shall stand covered by suitable erection insurance also for the value of 110% of the item. The charges for the insurance shall be borne by the Contractor.

4. **The Clause No. 14 of General Condition of Contract (GCC), Section-II is modified and shall be read as under:**

Guarantee:

The guarantee period shall be valid up to 18 (Eighteen) months with effect from the date of acceptance of the materials by DPA or 12 (twelve) months from the date of installation, whichever is earlier.

The Contractor shall warrant the Board that the goods and services under this contract will comply strictly with the contract, shall be first class in every particular case and, shall be free from defects. The Contractor shall further warrant the Board that all materials, equipment and the supplies furnished by him will be new and fit for their intended purposes.

The Board shall promptly notify the Contractor in writing of any claim arising under this Warranty. Upon receipt of such notice, the Contractor shall promptly repair or replace the defective goods and/or services at no cost to the Board.

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

If the Contractor, having been notified, fails to rectify the defects in accordance with the contract, the Board may proceed to take such remedial action as may be necessary, at the Contractor’s risk and cost.

5. **The Clause No. 30 of Section-II is replaced as under- Employer’s Obligation:** For execution of the work electricity will be provided, free of cost to contractor as per DPA Norms.
6. **The Clause No. 46 of Section-II is modified as under – Third Party Inspection:**

DPA shall appoint the TPIA for monitoring the work, if any observations/queries are made by Third Party Inspection Agency; the same shall be complied by Contractor before the next schedule visit. The TPIA will check and certify the same. Payment for subsequent RA bill may withhold if any queries raised by TPIA are not complied by Contractor (under the scope of works). The charges incurred for Third Party Inspection Agency will be borne by DPA.
7. **The clause no. 55 of GCC of Section-II is modified and shall be read as under Valid Electrical Contractor License and Electrical Supervisor Certificate:** The contractor shall have valid electrical contractor’s license issued by their respective state for carrying out electrical work of nature involved in this tender. The contractor shall also have a valid Electrical Supervisor’s certificate of competency, issued from the Commissioner of Electricity, Energy & Petrochemical Department, (Inspection wing), Block No.18, 6 th floor, Sector No. II, Udyog Bhavan, Gandhinagar, Government of Gujarat or equivalent authority from the other states/central Govt
- 8.
9. The contractor/service provider/supplier etc. has to ensure timely and proper filling of GSTR1 so that Deendayal Port Authority can avail input tax credit in timely manner. In case DPA not allowed input tax credit due to failure on part of the contractor/service provider/supplier etc., it will be a financial loss to the DPA and therefore same shall be recovered from the payment/deposit of the contractor/service provider/supplier.
10. **Integrity Pact:**

The “Procedure for signing Integrity Pact” is as follow:

 - (1) The Employer / Authorized Person of Employer has signed the IP in the presence of a witness from their side, who has also affixed his/her signature thereof and then the same IP has been uploaded on n-procure portal
 - (2) The potential bidders shall download and print the IP Agreement signed by the Employer and their witness and affix his/her signature on the IP Agreement in the presence of a witness from his/her side, who shall also affix his / her signature thereof. Having completed the signing procedure, the Potential Bidder shall upload the duly filled and signed IP Agreement on n-procure portal.
 - (3) The procedure mentioned above regarding signing of Integrity Pact Agreement by both the parties (Employer and Potential bidders) shall be

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

completed online.

However, in case of any technical glitch due to which if any potential bidder is unable to upload the IP Agreement, then he / she shall submit the Hard Copy of the duly filled, signed IP Agreement to the Department concerned of DPA within a period of seven days and prior to opening of the Technical Bid, failing which Bid of potential Bidder shall be treated as disqualified.

11. **The clause no. 10.2 of ITB of Section-I is modified and shall be read as under**

Pre-Bid meeting: Pre-Bid is not applicable.

**Signature & Seal
of Contractor**

-sd-

**Executive Engineer (E)
Deendayal Port Authority**

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

SECTION IV

FORMS OF BID

Part - I

To be submitted by Bidders with their Bids

NOS. OF FOMAT	NAME OF FORMS/FORMAT
1.	Form of application
2.	Pre-qualification of bidders
3.	Format for declaration
4.	Letter of authority for submission of bid
5.	Exceptions & Deviations
6.	Specimen EMD (Bank Guarantee Format)
7.	Bid security declaration form (For MSEs)

Part - II

To be used by successful Bidder

NOS. OF FORMAT	NAME OF FORMS/FORMAT
8.	Letter of Award
9.	Agreement form
10.	Specimen bank guarantee of Performance Guarantee / Security Deposit
11.	Letter of authority from bank for all BGs
12.	Format of Extensions (Part - I)
13.	Format of Extension (Part-II)
14.	Certificate to be issued by Third Party Agency on their Letter Head
15.	Certificate to be issued by Manufacturer on their letter head

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

Form -1

SPECIMEN OF APPLICATION

(To be executed on bidder’s letter head)

To

The Executive Engineer(E)

Deendayal Port Authority

(Address

)

Pin Code: _____

Dist- Kutch (Gujarat)

We, the undersigned, declare that:

(a) we have examined and have no reservations to the tender documents, including addenda and clarifications issued vide

(b) we offer to execute the work in conformity with the tendering documents and in accordance with the delivery schedules specified in the schedule of requirements in accordance with the tender document bearing no **(EL/WK/2830)**

(c) our tender shall be valid for the period of 120 days, from the date fixed for the tender submission deadline and it shall remain binding upon us and may be accepted at any time before the expiration of that period or any extended period.

(d) If our tender is accepted, we commit to submit a performance guarantee for the

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

due performance of the contract, as specified in specimen form for the purpose.

(e) No Joint Venture / Joint Venture.

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

(f) Our firm, its affiliates or subsidiaries- including any subcontractors or contractors for any part of the contract – has not been declared ineligible by the port, under laws of India or official regulations.

(g) We understand that this tender, together with your written acceptance thereof included in your notification of award, shall constitute a binding contract between us, until a formal contract agreement is prepared and executed.

I. We understand that you are not bound to accept the lowest evaluated tender or any other tender or you can also split the work that you may receive.

II. We also make a specific note clause of [ITB, NIT] under which the contract is governed.

Signed: [insert signature of person whose name and capacity are shown]

In the capacity of [insert legal capacity of person signing the form of tender] Name:[insert complete name of person signing the form of tender]

Duly authorized to sign the tender for and on behalf of: [insert complete name of tenderer]

Dated on _____ day of _____, _____ (insert date of signing)

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

Form -2

Specimen format for Pre-qualification of bidders

The information to be filled in by the bidder in the following pages will be used for purposes of pre-qualification as provided for in the instructions to Tenderer.

1. Only for individual bidders

1.1 Constitution of legal status of Bidder (Attach copy)

- Place of registration:
- Principal place of business
- (power of attorney of signatory of Bid (Attach)

2. Turnover of the Firm

Description	Year	Turn over
(insert the year as per PQC) i.e. last three financial years ending 31st march of the previous year	2021-22	
	2022-23	
	2023-24	

Attachment: financial reports for the last three years: balance sheet, profit and loss statements, auditor's reports (in case of companies/corporation) etc. List them below and attach copies.

Attested Copy of Annual Turnover during Last Three Year Ending on **March 24.**

3. Similar works

Particulars	Year	No. of Woks	Value
Total value of completed Similar work as defined in the tender document during last 07 years.	2017-18		
	2018-19		
	2019-20		
	2020-21		
	2021-22		
	2022-23		
	2023-24		

Attachments: Supporting documents, viz., Successful completion certificate from clients, other documentations to substantiate the similarity of work as per definition of "Similar Work". Employer reserves the right to verify the information:

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

4. Information on bid capacity (works for which bids have been submitted and works which are yet to be completed) as on the date of this bid.

1. Existing commitments and on-going works.

Description of work	Place & State	Contract No. & Date	Name & Address of Port or Dept.	Value of Contract in Rs.	Stipulated Period of Completion	Value of remaining to be completed	Anticipated date of completion
1	2	3	4	5	6	7	8

2. Works for which bids already submitted

Description of work	Place & State	Name & Address of Port or Dept.	Value of Contract in Rs.	Stipulated Period of Completion	Date when decision is expected	Remarks if any
1	2	3	4	5	6	7

Attach attested certificates.

5. Information on litigation history in which the bidder is involved.

Other party (ies)	Port	Cause of dispute	Amount	Remark involved showing present status.

6. Additional information bidder may like to submit

Duly authorized to sign this authorization on behalf of: (insert complete name of Tenderer)

Dated on _____ day of _____, _____ (insert date of signing)

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

Form-3

SPECIMEN FORMAT FOR DECLARATION

(To be executed on bidder's Letter Head)

To. _____

(Project title)

Ref: _____

The undersigned, having studied the pre-qualification submission for the abovementioned project, hereby states:

- (a) The information furnished in our bid is true and accurate to the best of my knowledge.
- (b) That, in case of being pre-qualified, we acknowledge that the Employer may invite us to participate in due time for the opening of Price bid of the Tender on the basis of provisions made in the Tender Documents to follow.
- (c) When the call for Tenders is issued, if the legal, technical or financial conditions, or the contractual capacity of the firm changes, we commit ourselves to inform you and acknowledge your sole right to review the pre-qualification made.
- (d) We enclose all the required pre-qualification data format and all other documents and supplementary information required for the pre-qualification evaluation.
- (e) We also state that no changes have been made by us in the downloaded tender formats and understand that in the event of any discrepancies observed, the tender hoisted on website of n-procure is full and final for all legal/contractual obligations.
- (f)** We also declare that, our firm has not been banned / de-listed by any government or PSUs.
- (f) We also give an undertaking that, we have not made any payment or illegal gratification to any person / authority connected with the bid process so as to influence the bid process and have not committed any offence under the PC Act in connection with the bid.

Date: _____ Place: _____

Name of Applicant: _____

Represented by (Name & capacity) _____

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

Form-4

SPECIMEN LETTER OF AUTHORITY FOR
SUBMISSION OF BID

(To be executed on Rs.300/- non Judicial Stamp Paper)

To

The

Dear Sir,

We _____ do hereby confirm that Shri (Name, designation and Address) is/are authorized to represent us to bid, negotiate and conclude the agreement on our behalf with you {copy of board resolution attached (in case of company)} for tender no. ----- for the work of _____ and his specimen signature is appended here to ..

We confirm that we shall be bound by all and whatsoever our said signatory shall commit. We understand that the communication made with him by the employer/Board shall be deemed to have been done with us in respect of this Tender.

[specimen signature]

Yours faithfully,

Signature:

Name & Designation:

For & on behalf of:

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

Form-5

<u>EXCEPTIONS AND DEVIATIONS</u>

As pointed out in the Tender Call Notice, Bidder may stipulate here exceptions and deviations to the bid conditions, if considered unavoidable.

Sr. No.	Page No. of Bid Document	Clause No.of Bid Document	Subject Deviation

Note: however, the Bidders may note that unacceptable deviations, if any, the bid shall be liable for rejection. Bidder is discouraged to deviate from bid conditions, specifications, delivery schedules, and commercial terms as per the tender document.

Duly authorized to sign this authorization on behalf of: [insert complete name of Tenderer]

Date on _____ day of _____, _____ [insert date of signing]

“Removing, Shifting & Re-erection the Electrical Substation equipment’s from 6th berth S/s to proposed location thereof inside cargo jetty area.”

Form -6

Specimen EMD (Bank Guarantee Format) (Not Applicable)

[The Bank shall fill in this Bank Guarantee Form in association with the instructions indicated. To be executed on Rs. 300/- non Judicial Stamp Paper]

(Bank's name and address of Issuing Branch or Office)

Beneficiary's Bank details area as under

Account No. 10316591671

IFSC Code : SBIN0060239

Beneficiary: (Name and Address of Employer/Board) The Board of Deendayal Port Authority

Date:

Tender Guarantee No.:

We have been informed that [name of the Tenderer] (hereinafter called "the Tenderer") has submitted to you its Tender dated (hereinafter called "the Tenderer") for the execution of [name of contract] under Invitation for Tenders No.[Number]. Furthermore, we understand that, according to your conditions, Tenders must be supported by an EMD.

At the request of the Tenderer, we [name of Bank] hereby irrevocably undertake to pay you any sum or sums not exceeding in total an amount of [amount in figures] ([amount in words]) upon receipt by us your first demand in writing accompanied by a written statement stating that the Tenderer is in breach of its obligation(s) under the Tender conditions, because the Tenderer:

(a) Has withdrawn its Tender during the period of tender validity specified by the Tenderer in the Form of Tender; or

(b) Having been notified of the acceptance of it's Tender by the Employer/Board during the period of Tender validity, (i) fails or refuses to execute the Form of Agreement, if required, or (ii) fails or refuses to furnish the performance guarantee, in accordance with the Instructions to Tenderers.

This guarantee will expire unless otherwise extended or informed by the Employer/ Board:

(a) If the Tenderer is the successful Tenderer, upon our receipt of copies of the contract signed by the Tenderer and the performance guarantee issued to you upon the instruction of the Tenderer; or

(b) If the Tenderer is not the successful Tenderer, upon the earlier of

(i) Our receipt of a copy of your notification to the Tenderer of the name of the successful Tenderer; or

(ii) Twenty-eight days after the expiration of the Tenderer's tender or any extended period thereof;

Consequently, any demand for payment under this guarantee must be received by us at the office on or before that date.

[Signature(s)]

[Authorization letter from the issuing bank that the signatory of this BG is authorized to do so should also be enclosed]

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof inside cargo jetty area.

(Applicable for MSME's)

Form-7

FORMAT OF BID SECURITY DECLARATION FROM BIDDERS
(On Bidders Letter head)

Bid Security Declaration Form

Date: _____ Tender No. _____

To (insert complete name and address of the Employer/ Purchaser)I/We.
The undersigned, declare that:

I/We understand that, according to your conditions, bids must be supported by a Bid Securing Declaration.

I/We accept that I/We may be disqualified from bidding for any contract with you for a period of **three** year from the date of notification if I am /We are in a breach of any obligation under the bid conditions, because I/We

a) have withdrawn/modified/amended, impairs or derogates from the tender, my/our Bid during the period of bid validity specified in the form of Bid; or

b) having been notified of the acceptance of our Bid by the purchaser during the period of bid validity (i) fail or reuse to execute the contract, if required, or (ii) fail or refuse to furnish the Performance Security, in accordance with the Instructions to Bidders.

I/We understand this Bid Securing Declaration shall cease to be valid if I am/we are not the successful Bidder, upon the earlier of (i) the receipt of your notification of the name of the successful Bidder; or (ii) thirty days after the expiration of the validity of my/our Bid.

Signed: (insert signature of person whose name and capacity are shown)
in the capacity of (insert legal capacity of person signing the Bid Securing Declaration)Name:
(insert complete name of person signing the Bid Securing Declaration)
Duly authorized to sign the bid for an on behalf of (insert complete name of Bidder)
Dated on _____ day of _____ (insert date of signing)

Corporate Seal (where appropriate)

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof inside cargo jetty area.

Form-8

LETTER OF AWARD FORMAT

No: _____

Date: _____

To _____

(Name and Address of the Contractor)

Sub: Tender No. _____ (Name of Work)

Ref : Your bid dated _____ And _____ (list the correspondence with the Bidder)

Dear Sirs,

With reference to your above offer and subsequent correspondences on the subject, we are pleased to inform you that your offer has been accepted by the competent authority and you are hereby requested to initiate actions for fulfilment of all necessary formalities, as indicated in the tender document for the above said work, at the earliest.

The Engineer-In-Charge for this work shall be Mr. _____.

Agreed Schedule date of commencement of the work is _____ and Schedule date of completion of the work is _____. Total Contract Price is Rs. _____.

You are requested to sign the Agreement and fulfil other formalities as per the Tender conditions.

Yours Faithfully,

(Signature of the controlling Officer) CHIEF

MECHANICAL ENGINEER

DEENDAYAL PORT AUTHORITY

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof inside cargo jetty area.

Form-9

SPECIMEN CONTRACT AGREEMENT

(To be executed on Rs.300-non-judicial stamp paper)

[The successful tenders shall fill in this form in Accordance with the instructions indicated]

This agreement made of this _____day of _____Two Thousand between the Board of Deendayal Port Authority a body corporate under Major Port Authorities Act, 2021 having its Administration Office Building at Gandhidham(Kutch) (hereinafter called the 'Board' which expression shall unless excluded by or repugnant to the context, be deemed to include their successors in office) of the one part and _____(Name and address of all the partners if a partnership with all their address) hereinafter called the 'Contractor' which expression shall unless excluded by or repugnant to the context be deemed to include his / their heirs, executors , administration , representatives and assignees or successors in office of the other part.

WHEREAS the Board is desirous to carrying out the work of

_____And whereas the Contractor has offered to execute and complete such work.

WHEREAS the Contractor has deposited the Performance security deposit @ 10% of contract price amounting to Rs. _____

In following manner for the due fulfillment of all the conditions of the contract

- (1) 5 %, Rs. _____ , paid in form of BG/FDR/Digital Transfer No.- _____(to be submitted within 21 days of issue of LOI)
- 2) Balance 5 % amount of Rs. _____ as to be recovered from the work bills.

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof inside cargo jetty area.

NOW THIS AGREEMENT WITHINNESS AS FOLLOWS: -

1. In this agreement words and expression shall have the same meaning as are respectively assigned to them in the general condition (including special conditions, if any) of contract hereinafter referred to.

2. The following documents shall be deemed to form and read as construed part of this agreement viz.:

i) Notice inviting tender.

ii) Technical specifications.

iii) Special conditions of contract.

iv) Tender submitted by the Contractor.

v) The Board's "Drawing".

vi) The schedule items of work with quantities and rates.

vii) Any correspondence made between the Executive Engineer(E) and the Contractor after opening of the cover-I—as regards to contain clarifications/details called for vice versa.

viii) Common terms and conditions offered to Contractor and their acceptance including confirmation to withdrawal of their own terms and conditions offered with the tender i.e 'Cover-I'.

ix) BG/FDR/Digital Transfer for security deposit.

All the disputes related to subject contract shall be resolved through a conciliation committee/councils comprising of independent subject expert.

3. The Contractor hereby covenants with the Board to complete the work of _____ in conformity in all respects, with the provisions of the contract.

4. The Board hereby covenants to pay the Contractor in consideration of such completion of the works, the contact price of Rs. _____ (Rupees _____ only) at the time and in the manner prescribed of the contract.

IN WITNESS WHERE of the parties here unto have set their hands and seals the day and year first above written signed and sealed by the Contractor in the presence of:-

Witness

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof inside cargo jetty area.

1. Name & Address _____ Signature of Contractor

Seal

2. Name & Address _____

Seal

Signed, sealed and delivered by Shri _____ on behalf of the Board in presence of

1. _____

2. _____ (Chief Mechanical Engineer)
Deendayal Port Authority

The common seal of the Board of Deendayal Port Authority affixed in the presence of:

1. _____

Secretary

2. _____

Deendayal Port Authority

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof inside cargo jetty area.

Form-10

SPECIMEN BANK GURANTEE TOWARDS PERFORMANCE

GUARANTEE/SECURITY DEPOSIT

(To be executed on Rs. 300/- non-judicial Stamp Paper)

To,

The Board of Deendayal Port Authority,

A.O. Building, P.O. Box No.50,

Gandhidham-Kutch.

1. In consideration of the Board of Deendayal Port Authority incorporated by the Major Port Authorities Act, 2021 (hereinafter called "The Board" which expression shall unless excluded by or repugnant to the context or meaning thereof be deemed to include the Board of Deendayal Port Authority, its successors and assigns) having agreed to exempt (hereinafter called the "contractor") (Name of the contractor/s) from the demand under the terms and condition of the contract, vide (Name of the Department)'s letter No. Date ___ made between the contractors and the Board for execution of _____ covered under Tender No. _____ dated (hereinafter called "the said contract") for the payment of Security Deposit in cash or Lodgement of Government Promissory Loan Notes for the due fulfilment by the said contractors of the terms and condition of the said contract, on production of a bank Guarantee for Rs. _____ (Rupees _____) only we, the (Name of the Bank and Address) _____ hereinafter referred to as "the Bank") at the request of the contractors do hereby undertake to pay to the Board an amount not exceeding Rs. _____ (Rupees _____) only against any loss or damage caused to or suffered by the Board by reason of any breach by the contractors of any of the terms and conditions of the said contract.

2. We, _____ (Name of Bank) (Name of Branch), do hereby Undertake to pay the amount due and payable under this guarantee without any demur merely on a demand from the Board stating that the amount claimed is due by way of loss or damage caused to or which would be caused to or suffered by the Board by reason of the contractors failure to perform the said contract. Any such demand made on the Bank shall be conclusive as regards the amount due and payable by the Bank under this Guarantee. However, our liability under this guarantee shall be restricted to any amount not exceeding Rs. _____ (Rupees _____) only.

3. We, _____ (Name of Bank and Branch), undertake to pay to the Board any money so demanded notwithstanding any dispute or disputes raised by the contractor(s) in any suit or proceeding pending before any Court or Tribunal relating thereto our liability under this present being absolute and unequivocal. The payment so made by us under this bond shall be a valid discharge of our liability for payment there under and the Contractor(s) shall have no claim against

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof inside cargo jetty area.

us for making such payment

4. We, _____ (Name of Bank and Branch), further agree with the Board that the guarantee herein contained shall remain in full force and effect during the period that would be taken for performance of the said contract and that it shall continue to be forceable till all the dues of the Board under or by virtue of the said contract have been fully paid and its claims satisfied or discharged or till the _____ (Name of the user department) of the said certifies that the terms and conditions of the said contract have been fully and properly carried out by the said Contractors and accordingly discharge this guarantee. PROVIDED HOWEVER that the Bank shall at the request of the Board but at the cost of the Contractors, renew or extend this guarantee for such further period or periods as the Board may require from time to time.

5. We, _____ (Name of Bank and Branch), further agree with the Board that the Board shall have the fullest liberty without our consent and without affecting in any manner our obligations hereunder to vary any of the terms and conditions of the said contract or to extend the time of performance by the said contract or to extend the time of performance by the said Contractors from time to time or to postpone for any time or from time to time any of the powers exercisable by the board against the said Contractors and to forebear or enforce any of the terms and conditions relating to the said contract and we shall not be relieved from our liability by reason of any such variation or extensions being granted to the contractors or for any forbearance, act or omission on the part of the Board or any indulgence shown by the board to the Contractors or by any such matter or thing whatsoever which under the law relating to sureties would, but for this provision, have effect of so relieving us.

6. This guarantee will not be discharged due to the change in the constitution of the Bank or the Contractor(s).

7. It is also hereby agreed that the Courts in [GANDHIDHAM] would have exclusive jurisdiction in respect of claims, if any, under this Guarantee.

8. We, Bank lastly undertake not to revoke this guarantee during its currency except with the previous consent of the Board in writing.

9. Notwithstanding anything contained herein:

(a) Our liability under this Bank Guarantee shall not exceed Rs. _____
(Rupees _____ only);

(b) This Bank Guarantee shall be valid upto _____; and

(c) We are liable to pay the guarantee amount or any part thereof under this Bank Guarantee only and only if you serve upon us a written claim or demand on or before (date of expiry of Guarantee)."

(i) Name of Beneficiary's Bank is State bank of india, Gandhidham.

(ii) IFSC No. of Beneficiary's Bank is SBIN0060239.

(iii) Bank Account No. of Beneficiary is 10316591671. Date day _of
_____ 20

For (Name of Bank)

(Name) Signature

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof inside cargo jetty area.

Form-11

SPECIMEN LETTER OF AUTHORITY FROM BANK FOR ALL BGs

(To be executed on Bank's Letter Head)

Date:

To,

The Board of Deendayal Port Authority,

Dear Sir,

Sub: Our Bank Guarantee No. _____ dated _____
_____ for Rs. favoring yourselves issued on a/c of M/s. _____

(Name of contractor).....

We confirm having issued the above mentioned guarantee favouring yourselves, issued on account of M/s. _____ validity for expiry up to date _____ and claim expiry date up to _____. We also confirm 1) _____ 2) _____ is/are empowered to sign such Bank Guarantee on behalf of the Bank and his/their signatures is/are binding on the Bank.

Name of signature of Bank Office

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof inside cargo jetty area.

Form-12

Deendayal Port Authority
Form of application by the Contractor for seeking extension of time

Part - 1

1. Name of Contractor
2. Name of work as given in the agreement
3. Agreement No.
4. Estimated amount put to tender
5. Date of commencement of work as per agreement
6. Period allowed for completion of work as per agreement
7. Date of completion stipulated in agreement
8. Period for which extension of time has been given previously:
 - (a) 1st extension vide EE's No. Dated Month Days
 - (b) 2nd extension vide EE's No. Dated Month Days
 - (c) 3rd extension vide EE's No. Dated Month Days
 - (d) 4th extension vide EE's No. Dated Month DaysTotal extension previously given.
9. Reasons for which extensions have been previously given (Copies of the previous application should be attached)
10. Period for which extension is applied for
11. Hindrance on account of which extension is applied for with dates on which hindrances occurred and the period for which these are likely to last.
 - a) Serial No.
 - b) Nature of hindrance
 - c) Date of Occurrence
 - d) Period for which it is likely to last
 - e) Period for which extension required for this particular hindrance(f)Overlapping period if any, with reference to item.....
- g) Net extension applied for
- h) Remarks, if any.

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof inside cargo jetty area.

Total period on account of hindrance mentioned above.....

Month.....Days

12. Extension of time required for extra work
13. Details of extra work and amount involved:
 - (a) Total value of extra work
 - (b) Proportionate period of extension of time based on estimated amount put to tender on account of extra work.

14. Total extension of time required for 11 & 12

Submitted to the Sub-Divisional Officer

Signature of Contractor

Dated

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof inside cargo jetty area.

Form-13

DEENDAYAL PORT AUTHORITY
APPLICATION FOR EXTENSION OF TIME

PART II

(To be filled in by the Sub-Divisional Office)

1. Date of receipt of application from..... Contractor for the work of in the Sub-Divisional Office.
2. Acknowledgement issued by S.D.O. vide his No dated
3. Remarks of S.D.O.
(on the reasons given by the contractor are correct and what extension, if any, is recommended by him. If he has not recommended the extension, reasons for rejections should be given.)

Signature of Divisional Officer

Dated:

(To be filled in by the Superintendent Engineer)

1. Date of receipt in the Divisional Office.
2. Superintendent Engineer's remarks regarding hindrances mentioned by the Contractor.

 - (1) Serial No.
 - (2) Nature of hindrance
 - (3) Date of occurrence
 - (4) Period for which hindrance is likely to last
 - (5) Extension of time applied for by the contractor
 - (6) Overlapping period, if any, giving reference to items which overlap.
 - (7) Net period for which extension is recommended
 - (8) Remarks as to why the hindrance occurred

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof inside cargo jetty area.

and justification for extension recommended.

3. Superintendent Engineer's recommendations:

(The present progress of the work should be stated and whether the work is likely to be completed by the date up to which extension has been applied for. If extension of time is not recommended, what compensation is proposed to be levied under clause 2 of the agreement?)

Signature of Executive Engineer

Date

Dy. HOD/SE's recommendations

Signature of Dy. HOD

Date

HOD's recommendations/approval.

Signature of Chief Mechanical Engineer

Date

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof inside cargo jetty area.

Form-14

(Applicable in case of Procurement of Equipment)

**(CERTIFICATE TO BE ISSUED BY THIRD PARTY AGENCY ON THEIR LETTER
HEAD)**

To,

M/s. Deendayal Port Authority,

Kandla (Kutch)

Gujarat, INDIA.

This is to certify that the (name of equipment) designed, manufactured and supplied to Deendayal Port Authority are conforming with the Quality Assurance and Standards as per proven design and Model No. / Drawings submitted by M/s _____ in the Tender No. _____ of Deendayal Port Authority.

Signature & Seal of Authorized

Representative of Classification Society.

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof inside cargo jetty area.

Form-15

(Applicable in case of Procurement of Equipment)

(CERTIFICATE ISSUED BY MANUFACTURER ON THEIR LETTER HEAD)

To,

M/s. Deendayal Port Authority,

Kandla (Kutch)

Gujarat, INDIA.

This is to certify that the proven design submitted with Bid conforms with all the standards and generic specifications of (name of equipment) given at Page No. of the Tender No. (insert tender no.) of Deendayal Port Authority.

Signature & Seal of Authorized

Representative of the Manufacture

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof in side cargo jetty area.

Section V

TECHNICAL SPECIFICATIONS & SCOPE OF WORK

Name of work – Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof in side cargo jetty area.

1.0 GENERAL:

- 1.1 All equipment and material shall be designed manufactured and tested in accordance with the latest applicable IEC standard.
- 1.2 Equipment and material conforming to any other standard, which ensures equal or better quality, may be accepted. In such case copies of English version of the standard adopted shall be submitted.
- 1.3 The electrical installation shall meet the requirement of Indian Electricity Rules-1956 as amended up to date; relevant IS code of practice and Indian Electricity Act-1910. In addition, other rules and regulations applicable to the work shall be followed. In case any discrepancy, the most stringent and restrictive one shall be binding.
- 1.4 The high-tension switchgear offered shall in general comply with the latest issues including amendments of the following standards but not restricted to them.

Technical specification 1

The work includes removal of old 500 KVA transformers, RMU shifting at proposed location. LT Panel and all the defective Equipment's deposited main store Kandla, from the respective substations with all handling equipment's, transportation, labour, loading unloading etc. as directed by EIC.

Technical specification 2

Re-Erection, Testing and Commissioning of supplied 500 KVA 11/0.433 KV indoor type distribution transformer at proposed site including transformer foundation and civil work. All cable termination in both HV & LV side including termination at LT panels as well as earthing of transformer as per IER. This includes Installation, testing & Commissioning of supplied RMU (Ring Main units) outdoor type SF6 filled, with various combinations of load break isolators & breakers. (including earthing- Erection of earthing by using GI strip (minimum 35mm strip) with earthing plate including cost of coal/salt to RMU). The Installation of 11KV Outdoor SF6 Insulated RMU covering erection, testing and commissioning with associated equipment including civil work, supply & laying of 11kv cable, cable jointing kit etc. of RMU. The permission of Electrical inspector for charging of RMUs is in bidder scope. RMU fencing as shown below is in the scope of bidder the length and width of the fencing before erection the drawing should be approved by Engineer-in Charge. Cable termination kits, cable laying is in bidder scope.

All the RMU Panel application shall be erected by using suitable size of M.S. channel (to be supplied & erected by contractor, as per each module approved foundation drawing) foundation bolts including grouting of the bolts of each Module RMU panel. Each RMU panel shall be connected with 2 separate and distinct earthing system. After installation of RMU panel, necessary test and trial are to be carried out for proper functioning of safety, devices, relay etc. and

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof in side cargo jetty area.

before charging RMU Panel, all the tests required under relevant ISS and IEC – Rules 1956 shall be carried out and the result shall be in conformity with specifications and copies of test results shall be furnished to Engineer-in-Charge. The work includes supply & fixing of required length of insulated Rubber Mat having withstand capacity up to 22 kV, the Rubber Mat shall be laid in such a way, near the panel for operation of RMU.

The complete work shall be carried out as directed by Engineer-in-Charge. The side cable fix/adopter box wherever necessary/required shall be provided. If required, some alteration / modification is in the scope of contractor as per the instructions of Engineer-in-Charge. The work includes all labour & material required for installations, testing and commissioning of RMU as directed by Engineer-in-Charge.

Technical specification 3

This includes supply at site HT, 11 KV XLPE armoured cable with aluminum conductor of size 3 C X 150 sq.mm. With ISI mark confirming to IS:7098 (Part-II) 1985 with up-to-date amendments and of approved make.

Cables is to be supplied in single length and cable with joint shall not be accepted. The price quoted by the contractor shall be inclusive of all taxes, VAT, excise duty, Octori packing and forwarding, insurance, transportation and unloading at site of work. No escalation in the rate of cable shall be accepted at later stage, the rate quoted shall be per meter length of the cable. The quantities of cable shown in Schedule "B" are tentative and contractor is required to assess the actual requirements before procuring the cable. The cable shall have marking at an interval of every meter, showing its progressive length after every meter so as to facilitate the measurement of total length after laying of cable.

Technical specification 4

This includes supply at site 1.1 KV grade, 3.5 Core x 300 sqmm Cable various as per schedule 'B' Aluminum conductor, XLPE insulated armored cable confirming to IS : 7098 (Part-I) 1985 with up to date amendments and of approved make with ISI mark. The cable shall have marking/embossing at the interval of every meter showing its progressive length. The contractor shall produce the routine test certificate during supply of cable at site. The rate shall inclusive of all taxes (excluded GST), duties, packing, forwarding, insurance, and transportation and unloading at site of work etc.

Technical Specification No. 5

This includes supply, installation, Testing & commissioning of outdoor type Load Point panel at site, the works also include, testing Commissioning of outdoor pedestal Load Point Panel with top canopy, Double door, handle with locking arrangement, dust, damp and vermin proof.

Load point Panel Fabrication/construction salient feature as under:- –

- ❖ The Load Point Panel board frame shall be fabricated from Heavy Duty CRCA sheet steel minimum 2.5 mm thick, pressed & shaped.
- ❖ The Board shall be enclosed by sheet steel of minimum 2.0 mm thickness smoothly finished & level, door & covers shall be made 1.6 mm thick sheet steel. Adequate stiffeners shall be provided wherever necessary.
- ❖ Dust & vermin proof Protection Class: - IP 52. 122
- ❖ Bottom Cable entry.
- ❖ All panel edges and door edges shall be reinforced against distortion. Cut outs shall be true in shape and devoid of sharp edges.

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof in side cargo jetty area.

- ❖ The complete structure shall be rigid, self-supporting free from vibration, twists & bends.
- ❖ The Load point panel shall be paint by simens grey paint & treated by 7 tank process DIP ZINC PHOSPHATING process.
- ❖ The panel then powder coated with an approved colour shade as per IS.
- ❖ The final finished thickness of paint film on steel shall not be less than 50 microns, and shall not be more than 80 microns.
- ❖ Finished painted appearance of equipment shall present an aesthetically, pleasing appearance, free from dents and uneven surfaces.

The Load Point Panel shall be specious for easy maintenance and shall be provided with following electrical Items.

- 1) 250 Amps 4P Changeover Switch (Bus coupler) - 1 No.
 - 2) 250 Amps, 10 KA, 4P MCCB. - 2 No's I/c.
 - 3) Digital VAF Meter - 1 Nos.
 - 4) Digital Energy Meter - 1 Nos.
 - 5) CT Coil Class 1, Tape Wound - 3 Nos.
 - 6) Phase R, Y & B Indication Lamp - 03 Nos.
 - 7) Control Fuse (Suitable Rating) for outgoing:-3 Nos.
 - 8) 6 O/g Ckt, 4P MCCB 10 KA, C Curve. - 6 No's O/g 125 Amps
 - 9) 63 Amp MCCB - 2 Nos.
- 9) Main Bus & Taps :- The board shall be provided with three phase and neutral busbars. Busbars shall be of uniform cross section throughout the length of the board and up to the incoming terminals of feeder circuit breaker/switch, The busbars shall be made of high conductivity aluminum alloy Bus bar joints shall be complete with high tensile steel bolt and washers and nuts. Busbars shall be thoroughly cleaned at the joint locations and suitable contact grease shall be applied just before making a joint, separate supports shall be provided for each phase of the busbars. If a common support is provided for all three phase, ant tracking barriers shall be incorporated. Busbars shall be adequately supported and braced to withstand the stresses due to the specified short circuit currents. Bus bar supports shall be made of hylum sheets; glass reinforced moulded plastic material or cast resin. All these components shall be mounted/erected in the Load Point Panel by means of suitable cadmium passivated hardware. The Panel shall be complete in all respects with cable glands, lugs for incoming and outgoing cables including interconnection with PVC insulated cable single core, standard copper conductor of 650/1100V grade. Load Point Legs shall be heavy duty MS steel with chemical treated free from corrosive & rust, in reinforced foundation of suitable design, base stand of Load Point Panel 300 MM height made from 35X35X5 MM or as per proposed in drawing , SS angle & 2 nos. SS Terminal for earthing. All hinges & support will be corrosive & maintenance free. The Load Point Panel shall be tested as per IS: 4237. Before Manufacturing the Load Point Panel, The relevant test certificate in support of Load point panel manufacturing, along with design & drawing shall be submitted to DPA for approval and also all Electrical accessories shall be used satirically as

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof in side cargo jetty area.

per Approved Make List of DPA.

Technical Specification No. 6

This includes laying of cable size up to size of cable up to various size 3.5/4.0 Core HT/LT armored aluminum Conductor XLPE Cable.

(a) In Rail Crossing/RCC Road Crossing through HDD: -

Cable shall be laid underneath by using {6" Boar Diameter} Horizontal Directional Drilling (HDD) method by putting suitable diameter HDPE (suitable for cable size up to HT 3CX 400 Sq.mm) HDPE pipe having strength 10Kg/sq.cm} shall in contractor scope), the contractor shall have arranged JCB Machine for excavation, water for drilling, de-watering pump, HDD equipment's at their own cost. The cable shall be pass through heavy duty HDPE pipe buried at nominal minimum depth 165 cm or according to construction of RCC Road/ Rail network or as per directed by EIC. For single cable individual DWC pipe shall be pass through a road /rail crossing, for separate cable; separate HDPE pipe shall pass through the Tunnel / trench. Lying of HDPE pipes coupled by HDPE socket only after standard length in excavated trench/tunnel and also sealing of HDPE pipe ends by suitable cap at every manhole. Back filling & dressing of excavated trenches as per specification. This includes all labour and material as directed by Engineer-in-Charge.

(b) **In Hard/soft Soil:** -

The cable shall be laid through excavation in soft/hard soil. The trench to be excavated 0.5 Mtr. Wide 1.5 Mtr. deep. The bed of 50mm of river sand shall be provided in the bottom of the excavated trench. The cable shall be laid over the bed of river sand. This includes providing & lying of half round RCC Pipe on cable lengthwise i.e. parallel to the cable and the gaps shall be filled by fresh river sand. The cable shall be covered by keeping half round heavy duty RCC NP 2 Pipe. The filling of the trench shall be done with by provided Sand cover (at least 50mm from cable surface) completely & followed by excavated stuff & should be watered and rammed properly to its original position. The excess excavated stuff shall be disposed off from the Site of work and spreaded in low laying area as directed. The DPT shall provide heat shrinkable straight through joint of relevant size of approved make specified in tender item no. 3 & 4 to be supplied by contractor, if the laying of cable shall be more than standard drum length. This includes all labour and material as directed by Engineer-in-Charge.

Technical specification no 7

This includes design, manufacture and supply at site Main LT Distribution Outdoor Panel suitable for 415 Volts, 3ph, 4 wire, 50 Hz. AC supply system including all switchgears and internal wiring. The panel shall be dust and vermin proof, single front type, indoor type, and fabricated from CRCA sheet steel of 2.0 mm. thickness. The panel shall be mounted on 75 mm. x 40 mm. "C" Channel. The panel shall be painted with SIEMENS grey paint. Before painting the panel, the surface treatment shall be carried out by 7-tank process. The panel shall be provided with metallic engraved/Radium film labels on front for identification of Incoming & Outgoing feeders as directed. The neoprene gaskets shall be provided on the periphery of the doors of all feeders. The sleeved electrolytic copper busbars with epoxy insulators with Bakelite support and separators shall be provided with colour code. The panel shall be complete in all respect with cable glands, lugs for incoming & outgoing cables and also shall be provided with 8 nos. of earthing terminals.

The panel shall be comprised with following accessories:

1. INCOMER FEEDERS

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof in side cargo jetty area.

Main Incomer Feeders (2 nos.).

The Main Incomer Feeder shall be provided with 2 nos. 630 Amps. X 415 Volts Triple Pole - MDO (Draw out type) ACBs (Air Circuit Breaker) with Microprocessor released over current, Short circuit and Earth fault relay for each feeder. The Digital Multi-function Meter 1 No. for each feeder with LCD display shall be provided with parameters like KWH, MD, Voltages of each phase, Line current for each Phase, P.F of each Phase, P.F average, Instantaneous kW, Frequency & Date & Time.

The LED Indication lamps 6 nos. for R, Y, B, ON, OFF and trip indication shall be provided on each feeder. The 3 nos. CTs having ratio of 630/5 Amps shall be provided for metering on each feeder and 4 nos. control fuses / neutral links are to be provided with each incomer & the control wiring shall be done with copper wire. The Incomers shall be mechanically and Electrically interlocked.

2. OUTGOING FEEDERS

A) OUTGOING FEEDERS TYPE-1 (4 Nos.):

This type of Outgoing Feeders shall be provided with 4 nos. 250 Amps. X 415 Volts, 35/36kA Breaking Capacity Triple Pole MCCB (Moulded Case Circuit Breaker) for each feeder. The LED Indication lamp 1 no. for ON indication shall be provided on each feeder. The control wiring & power wiring shall be done properly and the power wiring shall be brought up to the Power terminal block of suitable ampere capacity.

A) OUTGOING FEEDERS TYPE-2 (4 Nos.):

This type of Outgoing Feeders shall be provided with 4 nos. 125 Amps. X 415 Volts, 35/36kA Breaking Capacity Triple Pole MCCB (Moulded Case Circuit Breaker) for each feeder. The LED Indication lamp 1 no. for ON indication shall be provided on each feeder. The control wiring & power wiring shall be done properly and the power wiring shall be brought up to the Power terminal block of suitable ampere capacity.

C) OUTGOING FEEDERS TYPE-3 (3 Nos.): This type of Outgoing Feeders shall be provided with 4 nos. 63 Amps. X 415 Volts, 35/36kA Breaking Capacity Triple Pole MCCB (Moulded Case Circuit Breaker) for each feeder.

The LED Indication lamp 1 no. for ON indication shall be provided on each feeder. The control wiring & power wiring shall be done properly and the power wiring shall be brought up to the Power terminal block of suitable ampere capacity.

The panel shall be designed, fabricated and supplied from manufacturers who are having type test certificate holders, i.e. CPRI/ERDA of similar capacity not less than 3 years. Before manufacturing the panel the drawing of panel shall be submitted for approval of KPT. The material shall be used from approved make list and got approved from Engineer-in-Charge.

Technical Specification No.8

This includes erection / Installation, testing and commissioning of 630 A x 415/500V 15 Way L.T distribution panel, dust and vermin proof, free standing, compartmentalized, fabricated from 2mm thick SWG CRCA sheet steel.

The cubical panel shall be firmly installed in proposed new substation at proposed location the trench line with proper size of foundation bolts on "C" channel of 75 x50 x 6 mm size after proper alignment of the panel. The channel shall be properly grouted on the floor / CC foundation using proper size of grouting bolts as desired by Engineer-in-charge.

This includes end terminations of Incoming and outgoing cables in all respect with cable glands, lugs for incoming & outgoing cables and also connections of earthing with 2 nos. of earthing terminals with supplied panel. The panel shall be commissioned as per relevant IS specification and IE rules-1956 with update amendments. The results of the test shall be confirming to the relevant IS specification

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof in side cargo jetty area.

and copies of the results shall be furnished to Engineer-in-charge by Contractor. The work includes all labour and material including necessary civil work as directed by Engineer-in-Charge.

Technical Specification No.9

This includes supply at site, laying, fixing and connecting of G.I strip of size 25x3 mm from earth station/existing earthing system to Transformer, H.T panel, H.T isolator, L.T panel etc as the case may be. This also includes laying and connecting of transformer neutral shall be earthed with two separate distinct copper flat of size 25x3mm. The copper strip shall be properly buried in the ground / flooring including the floor shall refill as per original. The strip shall be connected through copper nut, bolt and washer of size not less than 12mm etc.

The G.I strip also shall be laid from earth station to HT panel/LT Panels/Isolator etc. directly to two separate and distinct earths, buried in the ground / pucca trench / wall as the case may be and shall be clamped suitably wherever it is possible.

The work includes all material & labour required shall done as directed by Engineer-in-charge.

General:

- I) The earthing system shall conform to relevant provisions of code of practice under IS:3043 and shall be carried out in accordance with requirement of IE Rules 1956 as amended from time to time.
The following are practically applicable:
Rule No: 32,51,61,67,68,69 & 90.
- II) All medium voltage equipments shall be earthed by two separate & distinct connections with earth through earth electrode.
- III) In case of high voltage, the neutral point shall be earthed by not less than two separate & distinct connections with the earth having its own electrodes.
- IV) The metal conduit, trucking, cable sheath, switchgear, distribution board, feeder pillar, Armour of the cable shall be connected by two separate & distinct connections with the earth.
- V) The neutral point of distribution transformer shall be connected directly to the earth through copper flats having distinct earth points.
- VI) The value of the earth system resistance shall not be more than 5 Ω .
- VII) The earth electrode shall be designed to have a loading capacity adequate for the system for which it forms a part i.e. it should be capable of dissipating without failure of energy in the earth path at the point at which it is installed under any condition of operation of the system. The contractor shall prepare & submit six sets of drawing showing the main earth connection & earth electrodes.

Technical Specification No.10

- 1) This includes preparation of earth station with chemical treated back filled compound 50 mm dia Pipe In Pipe GI Type 2 Mtr Depth , Maintenance free including all accessories & Masonry work Enclosure with cover plate.
2. A cement concrete (ratio 1:4:8) chamber of at least 30 Cm. x 30 Cm. shall be provided just below the surface of ground over the funnel for watering and having RCC/CI cover of suitable size as directed. This also includes removal of extra-excavated earth from the site. The work shall be carried out to entire satisfaction of Engineer-in-charge. This work includes all labour and material as directed by Engineer-in-Charge. The works also include earthing value marking

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof in side cargo jetty area.

& painting on earth strips & earthing station by suitable paints (Green Color on Strips) and also mentioned the earth value on earth pits.

Technical Specification No. 11

Supply of 3 of 3 phase 500 KVA 11/0.433 KV indoor type distribution transformer.

1. Rating : 500 KVA
2. Voltage Ratio : 11/0.433 KV
3. Vector Group : Dyn-11
4. Tapping Range/steps : - 5 % to 12.5 % in steps of 2.5 %
5. Tap Changer : Off Circuit
6. Temperature Rise(Oil/wdg.) : 40/45 Degree centigrade
7. Terminations
HV : Cable Box
LV : Cable Box
8. Fittings : As per enclosed list of Annexure-I
9. Paint : Epoxy Shade 632

Annexure - I

1. Rating and Diagram Plate
2. 2 Nos. Earthing Terminals
3. Lifting Lugs for main tank and for all items to be handled independently
4. Drain cum filter Valve with Plug at Bottom
5. Filter valve with plug at Top
6. 6" Dial type oil thermometer with 2 contacts
7. 6" Dial type winding thermometer with 2 contacts
8. Conservator with oil filling hole with cap and drain plug
9. Silica Gel Breather
10. Air release plug
11. Off Circuit externally operated tapping switch position indicator, handle and locking device for - 5% to 12.5% voltage variation in steps of 2.5%
12. 3 Nos. Thermometer pockets
13. Explosion vent with Double Diaphragm and oil sight Glass
14. Radiator bank mounted on tank complete with Air Release Plug Drain Plug and isolating valves at points of connection with tank
15. 4 Nos. Bidirectional flat rollers
16. Marshalling Box
17. 1 No. Buchholz rely with A/T contacts with shut off valve

TERMINATIONS:

HV: Cable box to receive 1 no. 3 core suitable size of 11 KV XLPE cable

LV: Cable box to receive suitable nos. and size of 1.1 KV grade armoured cables

Orientation: 180 Degree, H.V. cable box to L.V. cable box

Neutral terminal shall be brought out for solid earthing.

NOTES:

1. Lugs Glands termination kits are in your scope of supply.
2. PAINT: The transformers shall be painted as under:
 - a) Internally with oil resisting varnish paint
 - b) Externally with 1 coat zinc chromate followed by two coats of epoxy paint shade 632 if IS-5.

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof in side cargo jetty area.

3. Following routing tests as per IS shall be carried out during inspection of transformer at your works.
- Winding Resistance Measurement Test
 - No Load Loss Measurement Test
 - Full Load Loss Measurement Test
 - Separate Source Voltage Test
 - Insulation Resistance Test
 - Turns Ratio Test
 - Polarity Phase Relationship Test
 - Breakdown Value Test (Die Electric Strength test) of Transformer Oil.
 - Impedance Voltage of Transformer
 - Heat run test will be carried out for the transformer having higher Full Load losses.

Yours scope of supply is limited to Design, Engineering Manufacture, Assembly, Testing, Packing and Forwarding and delivery of transformer complete with all fittings and accessories.

Technical Specification No. 12

Erection, Testing and Commissioning of supplied 500 KVA 11/0.433 KV indoor type distribution transformer at site including transformer foundation and civil work. All cable termination in both HV & LV side including termination at LT panels as well as earthing of transformer as per IER. If any alteration/modification required is in the scope of contractor. The work includes all material, tools, equipment and labour and as per direction of EIC.

Technical Specification No. 13

This item includes supply at site 4 Way double door TPN DB with IP42 degree of protection. The DB shall be made from special grade of CRCA sheet and powder coated. The DB shall be fitted with Bus bar, DIN Rail and neutral link. The rates shall be excluding the cost of MCBs.

Technical Specification No. 14

This item includes fixing & commissioning of supplied double door TPN DB on wall/ structure of Substation at 34 Hectare area as directed. The DB shall be fixed rigidly on wall through suitable size of nut bolts/anchor fasteners/cemented wooden gutties as directed. This includes necessary wiring, connections & earth linking with all material, labour tools & tackles as directed by Engineer-In-charge.

Technical Specification No. 15

- (a) This includes supply of DIN Rail mounted 'C' Series 40 Amp, 415 Volts, 50 Hz Triple Pole Neutral (TPN) MCB with 10kA Breaking Capacity. The supplied MCB shall conform to IS 8828 or IEC 60898-1.

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof in side cargo jetty area.

- (b) This includes supply of DIN Rail mounted 'C' Series 32 Amp, 415 Volts, 50 Hz Single Pole (SP) MCB with 10kA Breaking Capacity. The supplied MCB shall conform to IS 8828 or IEC 60898-1.

Technical Specification No. 16

This includes fixing & commissioning of supplied TPN/SP MCB in existing TPN double door DB on wall / structure. The MCB shall be fixed on DIN Rail provided in existing DB. This includes necessary wiring, connections, distribution & earth linking of DB with all material, labour tools & tackles as directed by Engineer-In-charge.

Technical Specification No. 17

This item includes providing & fixing surface wiring for single phase sub-circuit from the Distribution Board/MCB to the switchboard with Flame Retardant, 1100 Voltage grade, single core stranded copper conductor PVC insulated wire with IS: 694/1990 of size 2.5 sq. mm. for phase & neutral wire and 1.5 Sq.mm continuous stranded copper conductor wire for earth to be laid through PVC Oval Pipe with IS: 9537 (Part-III) of size 25 mm Diameter of Medium Mechanical Strength (MMS) type/oval shape PVC conduit pipe of 25mm and other accessories such as Tee, junction box, inspection bends, elbow etc. of approved make as directed by Engineer-in-Charge. The PVC oval conduit shall be fixed rigidly on wall/ceiling with suitable size heavy duty PVC saddle set with base, clamp & screw at the interval of 0.5 meter. Complete work consists of necessary wiring connections and earth linking at both the ends with all materials and labour as directed by Engineer-in-charge.

Technical Specification No. 18

This item includes providing & fixing surface wiring for light/tube light point from switchboard with Flame Retardant, 1100 Voltage grade, single core stranded copper conductor wire with IS 694: 1990 of size 1.5 sq. mm for phase & neutral wire and 1.0 Sq. mm continuous stranded copper conductor wire for earth to be laid through PVC Round Pipe with IS 9537 (Part-III) of size 20 mm Diameter of Medium Mechanical Strength (MMS) type /20mm oval shape PVC conduit pipe of 20 mm and other accessories such as Tee, junction box, inspection bends, elbow etc. of approved make as directed by Engineer-in-Charge. The PVC round /oval conduit shall be fixed rigidly on wall /ceiling with suitable size heavy duty PVC saddle set with base, clamp & screw at the interval of 0.5 meter. The work consists of providing & fixing of Bell Push /Flush type SP switch 6A, 240V semi modular Anchor Nova type or equivalent with ISI mark and to meet specifications of IS 3854 & 3 plate Ceiling Rose /Angle Holder made from polycarbonate on suitable size of PVC box with cover. The PVC box shall be rigidly fixed with cemented wooden gutties on the wall and the switches shall be fixed on cover of the box. The complete work consists of necessary wiring connections and earth linking at both the ends with all materials and labour as directed by Engineer-in-charge.

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof in side cargo jetty area.

Technical Specification No. 19

The item includes providing & fixing surface wiring for Power point with Flame Retardant, 1100 Voltage grade, single core stranded copper conductor wire with IS 694: 1990 of size 2.5 Sq. mm for phase & neutral wire and 1 Sq. mm continuous stranded copper conductor wire for earth to be laid through PVC Round Pipe with IS 9537 (Part-III) of size 20 mm Diameter of Medium Mechanical Strength (MMS) type /20mm oval shape PVC conduit pipe and other accessories such as Tee, junction box, inspection bends, elbow etc. of approved make as directed by Engineer-in-Charge. The PVC round /oval conduit shall be fixed rigidly on wall /ceiling with suitable size heavy duty PVC saddle set with base, clamp & screw at the interval of 0.5 meter. The work consists providing & fixing of 20 A & 10 A, 5 in 1 combined Unit 240V, 50Hz with switch, socket, fuse & indicator with ISI mark. The Combined unit shall be rigidly fixed with cemented wooden gutties on the wall as directed. The complete work consists of necessary wiring connections and earth linking at both the ends with all materials and labour as directed by Engineer-in-charge.

Technical Specification No. 20

This item includes supply at site and installation of environmental friendly energy efficient 20W LED tube fixture complete with batten (T8). The fixture should be of low power consumption & having high efficiency. This includes fixing & commissioning of supplied 20 W LED tube fixture complete with batten on wall/ceiling at suitable height by screws, gutties & necessary connections with ceiling rose including all required material and labour as directed by Engineer-In-Charge.

Technical Specification for LED 20W tube fixture:

No.	Parameter	Specification
1	Power Consumption	20 Watt
2	Rated Voltage	220-240 VAC.
3	Rated Luminous flux	≥2000 Lm
4	Beam angle	> 120 degrees
5	Power Factor	≥0.90
6	IP	IP20
7	Tube Efficiency (Lm/w)	≥95
8	Power Factor	≥0.90
9	Life Expectancy	About 30,000 burning hours.
10	Input Frequency	50 Hz.
11	CRI	Minimum 85
12	CCT	4000-6500K
13	Certification preferred	LM 79/LM 80

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof in side cargo jetty area.

Technical Specification No. 21

This item includes supply at site, exhaust fan of size 300 mm with capacitor start and run type motor, continuously rated, totally enclosed fitted with heavy duty grease filled double ball bearing that ensures noiseless performance and long lasting smoother life of fan suitable for single phase 230 Volt AC 50Hz. The impeller shall be used in an Exhaust Fan shall be of the propeller type & both hub and impeller shall be dynamically balanced, frames and arms mounted on rubber bushings, to avoid vibrations.

Technical Specification No. 22

This item includes fixing & commissioning of supplied 300mm sweep exhaust fan on existing exhaust hole so that discharge of exhaust air can be done easily. However, if exhaust hole is not provided, it is to be done by contractor. The grouting of the fan is to be done by suitable size of anchor fastener bolts, and by providing metallic mesh/louvers as directed to other side so that birds can be restricted in the passage. This includes connections with 3 core flexible copper cable from nearest source of supply & necessary connections & earth linking with all material and labour and as directed by Engineer-In-Charge.

Technical Specification No. 23

This includes providing of heat shrinkable straight through joint kit suitable for HT XLPE power cable jointing to HT 3 Core X 150 sq mm.
The supply of cable joint kits as per approved make like 3M/Raychem/ASCON/YAMUNA DENSON.

Technical Specification No. 24

This includes fixing of heat shrinkable straight through joint suitable for 3 Core X 150 sq mm grade. This including fixing of all required materials and by validated person work will be carried out. The joint shall be made in such a way that the joint shall be electrically and mechanically permanent. The work includes all labour, tools tackles, joint kit of approved make and as directed by Engineer-in-Charge.

Technical Specification No. 25

This includes supply of following type End termination HT XLPE 3C X 150 Sq.mm indoor kit as per approved make like 3M/Raychem/ASCON/YAMUNA DENSON. Any Major activity and query about work related to be discussed with Engineer-in-Charge and finalized as per his directions.

Technical Specification No. 26

This include making/fixing of following type End termination HT XLPE indoor kit HT 3CX 150 Sq.mm. This including fixing of all required materials. The joint shall be made in such a way that the joint shall be electrically and mechanically permanent. The work by validated person will be carried out includes all labour, tools tackles, joint kit of approved make and as directed by Engineer-in-Charge.

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof in side cargo jetty area.

Technical Specification No. 27

- a) This includes supply of heat shrinkable straight through joint kit suitable for LT 1.1 KV XLPE power Aluminium armoured cable having size up to 4 Core X 35 sq. mm The cable joint kits shall be supplied as per approved make.
- b) This includes supply of heat shrinkable straight through joint kit suitable for LT 1.1 KV XLPE power Aluminium armoured cable having size up to 4 Core X 70 sq. mm The cable joint kits shall be supplied as per approved make.

Technical Specification No. 28

- a) This includes fixing of heat shrinkable Straight through joint suitable for LT 4 Core X 35 sq mm 1.1 KV, Aluminium armored cable. This including fixing of all required materials. The joint shall be made in such a way that joined section can be reeled without sagging and also joint shall be electrically and mechanically permanent. The work includes all labour, tools tackles, joint kit of approved make and as directed by Engineer-in-Charge.
- b) This includes fixing of heat shrinkable Straight through joint suitable for LT 4 Core X 70 sq mm 1.1 KV, Aluminium armored cable. This including fixing of all required materials. The joint shall be made in such a way that joined section can be reeled without sagging and also joint shall be electrically and mechanically permanent. The work includes all labour, tools tackles, joint kit of approved make and as directed by by Engineer-in-Charge

Sd/-

Signature & Seal of Contractor

Executive Engineer (E)
Deendayal Port Authority

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof in side cargo jetty area.

SECTION - VI

Schedule-B

Name of Work: Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof in side cargo jetty area.

Sr. No.	Description	Qty.	Unit	Rate	Amount
Part A : Electrical Item					
1	Removing & shifting of the following equipment's as per Tech Spec. No:-1 a) 500 KVA Distributions Transformer. b) RMU of 12 KV, 630 Amps 21 KA Outdoor mounted RMU Unit. c) LT panel (Way-15)	1 1 1	No No No		
2	Re-Erection, Testing & commissioning of the following equipment's as per Tech. Spec. No. 2 a) 500 KVA Distributions Transformer. b) RMU of 12 KV, 630 Amps 21 KA Outdoor mounted RMU Unit	1 1	No. No		
3	Supply at site 3 Core armoured HT aluminium conductor XLPE cable of 11 KV grade, following rating of the as per Technical Specification No. 3 A). 3C X 150. Sq. mm.	400	Mtr		
4	Supply at site 4 Core armoured LT aluminium conductor XLPE cable of 1.1 KV grade, following rating of the as per Technical Specification No. 4 A) 3.5C X 300 Sq. mm.	300	Mtr.		

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof in side cargo jetty area.

5	Supply, Installation Testing & Commissioning at site of following 11-way LT Load point Panel (as per proven design) as per Technical Specification No. 5 11 Ways {2 I/C, 1 Changeover (Bus Coupler), 8 O/G}.	1	Nos.		
6	Laying HT/LT armoured aluminium conductor cable 3.5/4 Core up to 35 Sq. mm. to 150 Sq. mm. as per Technical Specification No. 6 a) Through HDD, with HDPE Heavy Duty Pipe. b) In Existing RCC Trench c) Hard & soft Soil	150 200 350	Mtr. Mtr. Mtr.		
7	Supply at site following way LT Distribution Panel (as per proven design) as per Technical Specification No. 7 15 Ways (2 I/C, 1 Bus Coupler, 12 O/G).	1	No.		
8	Installation, Testing & commissioning of LT Distribution Panel as per Technical Specification No. 8	1	No.		
9	Providing & connecting following type of earth wire from Earth Station to Equipment as per requirement as per Tech. Spec. No. 9 a) 25 X 3 mm. Copper Strip. b) 25 X 3 mm. Hot DIP GI Strip. c) 8 SWG GI Earthing Wire	25 80 50	Mtr. Mtr. Mtr.		
10	Supply & Preparation of Earthing Station, TFC, Chemical Treated back filled compound earthing system as per Technical Specification No. 10 a) Pipe-In-Pipe 50-60 mm. Dia. GI type 3 Mtr. depth, for Transformer body earth, Maintenance free.	12	Mtr.		

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof in side cargo jetty area.

11	Supply of 3 phase 500 KVA 11/0.433 KV indoor type Distribution Transformer as per Technical Specification No. 11	1	No.		
12	Installation, testing & commissioning of 500 KVA 11/0.433 KV indoor type Distribution Transformer as per Technical Specification No. 12	1	No.		
13	Supply of TPN Double Door IP 42 DB 4 ways Distribution Board as per Technical Specification No. 13	1	No.		
14	Fixing of TPN Double Door IP 42 DB 4 ways Distribution Board as per Technical Specification No. 14	1	No.		
15	Supply of following type of MCB as per Technical Specification No. 15				
	a) 40A TPN MCB with 10kA Breaking Capacity	1	No.		
	b) 32A SP MCB with 10kA Breaking Capacity	3	No.		
16	Fixing of TPN/SP MCBs with 10 kA Breaking Capacity as per Technical Specification No. 16	4	No.		
17	Providing & fixing of surface wiring with 2 X 2.5 Sq. mm. copper conductor with PVC insulated (single phase and neutral) for single phase sub-circuit from the DB/MCBs to the switch board as per Technical Specification No. 17	30	Mtr.		
18	Providing and fixing surface wiring with 1.5 Sq. mm. copper conductor for light /tube point with PVC insulated single core standard copper conductor wire as per Technical Specification No. 17	18	No.		

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof in side cargo jetty area.

19	Providing and fixing surface wiring for 20A & 10A, 240 Volt, 50Hz Power point as per Technical Specification No. 19	1	No.		
20	Supply & Installation of surface mounted 20 Watt LED Tube light luminary complete with batten as per Technical Specification No. 20	12	No.		
21	Supply at site 300mm sweep exhaust fan as per Technical Specification No. 21	3	No.		
22	Fixing of 300mm sweep exhaust fan as per Technical Specification No. 22	3	No.		
23	Supply of Heat shrink straight through Joint kit for 11KV, 3C x 150 Sq.mm H.T XLPE cable as per Technical Specification No. 23	12	No.		
24	Fixing the Heat Shrink Straight through Joint kit for 11KV 3C x 150 Sq.mm H.T XLPE cable as per Technical Specification No.24	12	No.		
25	Supply of Heat shrink long sleeve & boat, suitable for RMU End termination kit (Indoor Type) for 11KV 3C x 150 Sq.mm H.T XLPE cable as per Technical Specification No. 25	8	No.		
26	Fixing of Heat shrink long sleeve & boat, suitable for RMU End termination kit (Indoor Type) for 11KV 3C x 150 Sq.mm H.T XLPE cable as per Technical Specification No. 26	6	No		
27	Supply of heat shrink straight through Joint kit of 1.1KV XLPE 4 Core Aluminum armoured cable of following sizes as per Technical Specification No.27				
	a) LT 4C x 35 Sq.mm cable	05	No.		
	b) LT 4C x 70 Sq.mm cable	05	No.		

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof in side cargo jetty area.

28	Making of heat shrink straight through Joint Kit suitable for L.T. 1.1 KV XLPE 4 Core armoured cable of following size as per Technical specification No.28 a) LT 4C X 35 Sq. mm. cable b) LT 4C X 70 Sq. mm. cable	05 05	No. No.		
----	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--------------	----------------	--	--

Total:

(In words Rupees _____ only)

(Note : The rates should be inclusive of all taxes, duties, fees, cess etc. and all incidental charges; but exclusive of GST)

Signature & Seal of Contractor

Executive Engineer (E)
Deendayal Port Authority

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof in side cargo jetty area.

SECTION VII

EVIDENCE TOWARDS SITE VISIT

I, Shri _____ authorized representative of M/s. _____
_____ (authorization letter issued by the firm with my specimen
signature and passport size photo and adhaar card are enclosed) have visited the
site on _____ with DPA representative Shri _____,
(Designation) _____ for the work of "Removing, Shifting & Re-erection the
Electrical Substation equipment's from 6th berth S/s to proposed location thereof
in side cargo jetty area." and inspected the site and other issues related to tender
to my satisfaction.

Seal, name and signature of the bidder	Name, designation and signature of DPA representative who assisted bidder during site visit.	Seal, name and signature of AXEN (E)

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof in side cargo jetty area.

SECTION VIII

Approved Make List for Electrical Items

Sr. No.	Description	Recommended Makes
1	HT VCB	SIEMENS / CROMPTON GREAVES/ABB/Schneider
1(a)	HV Gas Insulated Breakers	SIEMENS /Schneider/ABB
2	POWER TRANSFORMERS	VOLTAMP/CROMPTON GREAVES /BHARAT BIJLEE/ BHEL/ SIEMENS/ ABB/ Schneider/T&R
3	DISTRIBUTION TRANSFORMERS	EMCO/KIRLOSKAR/PATSON/VOLTAMP/ ABB / Schneider / T&R
4	RESIN CAST TRANSFORMERS	
	A) RESIN CAST IMPREGNATED	VOLTAMP / KIRLOSKAR / EMCO
	B) DRY CAST	VOLTAMP/KIRLOSKAR/EMCO
5	HT XLPE CABLES	POLYCAB/TORRENT/RPG ASIAN/ /GLOSTER/ UNISTAR/ UNISTAR/KEI/FINOLEX/HAVELS
6	LT XLPE CABLES	POLYCAB/TORRENT/RPG ASIAN/ / RALLISON/PRIMECAB/ HAVELLS/ UNISTAR/AVOCAB / ADCAB
7	LT ACB	SIEMENS/L&T/SCHNEIDER/C&S
8	PROTECTION RELAYS	AREVA/L&T/SIEMENS/ABB/C&S
9	LT PANEL	CPRI APPROVED
10	CHANGE OVER SWITCH	SIEMENS/L&T/ABB/C&S/SCHNIDER/ LEGRAND / INDOASIAN
11	SFU FOR MAIN LT DISTRIBUTION PANELS	SIEMENS/L&T/ABB/C&S
12	SFU FOR DISTRIBUTION PANELS & FEEDER PILLERS	SIEMENS/L&T/ABB/C&S/ SCHNEIDER/ LEGRAND/ INDOASIAN/HAVELLS
13	MCCB FOR MAIN LT DISTRIBUTION PANELS	SIEMENS/L&T/ABB
14	MCCB FOR DISTRIBUTION PANELS AND FEEDER PILLERS	SIEMENS/L&T/ABB/C&S/ SCHNIDER/ LEGRAND/ INDOASIAN/HAVELLS
15	MCB/ELCB/RCCB/ RCCBO FOR MAIN LT DISTRIBUTION PANELS	SIEMENS/HAGER L&T/ABB
16	MCB FOR DISTRIBUTION PANELS AND FEEDER PILLERS	SIEMENS/L&T/ABB/C&S/ SCHNEIDER/ LEGRAND/ INDOASIAN/ HAVELLS/ STANDARD
17	MCB DISTRIBUTION BOARD	STANDARD / HENSEL/LEGRAND / INDOASIAN / HAVELLS
18	MULTI FUNCTION DIGITAL METER FOR MAIN LT DISTRIBUTION PANELS/DIGITAL KWH	L&T/ENERCON/SECURE/L&G/ RISHABH

Operation & Maintenance Contract of Industrial Lighting at cargo handling area, open plots, jetty area, Godowns, Street lighting connecting to port gates including maintenance of 11/0.433KV Substation inside cargo jetty area for a period of two years.

	METERS	
19	ANALOG VOLT/AMPERE METER FOR DISTRIBUTION PANELS AND FEEDER PILLERS	RISHABH/AE/ENERCON/L&T
20	SELECTOR SWITCH FOR VOLTMETER/AMPERE METER	L&T/SIEMENS/C&S
21	POWER CONTACTOR & OVER LOAD RELAYS	L&T/SIEMENS/ABB
22	QUARTZ TIME CLOCK SWITCH	L&T/INDOASIAN/SIEMENS
23	PVC WIRE WITH COPPER CONDUCTOR	RR KABEL / KEI / POLYCAB/MILEX/GUJCAB/ STANDARD / FINOLEX / ANCHOR
24	FLUSH TYPE SWITCHES, SOCKETS, HOLDERS AND CEILING ROSES & ELECTRONIC REGULATORS	ANCHOR/MK/NORTHWEST/VINAY /PANAMA / HAVELLS
25	DOOR BELLS/CALL BELLS	ANCHOR/LEGEND/MK/NORTHWEST
26	MODULAR SWITCHES, SOCKETS, PLATES & BOXES	ANCHOR / MK / NORTHWEST / LEGRAND /HAVELLS / INDOASIAN / SIMENS.
27	PVC CONDUIT/OVAL CONDUIT & CASSING CAPPING AND ACCESSORIES	PRECISION/VULCAN/FINOLEX/ GARWARE/ RESTOPLAST/ SWASTIK / BPI
28	GLS LAMPS & FLUORESCENT LAMPS	PHILIPS / BAJAJ / WIPRO / CROMPTON GREAVES / OSRAM / SURYA ROSHNI / GE
29	HPSV, HPMV & METAL HELIDE LAMPS	PHILIPS / BAJAJ / WIPRO / CROMPTON GREAVES / OSRAM / SURYA ROSHNI / GE
30	IGNITORS FOR HPSV, METAL HELIDE LAMPS	PHILIPS / BAJAJ / WIPRO / CROMPTON GREAVES / OSRAM / SURYA ROSHNI / GE
31	LUMINARIES	PHILIPS / BAJAJ / WIPRO / CROMPTON GREAVES / OSRAM / SURYA ROSHNI / GE/C&S
31a	LED LUMINARIES	Philips /Bajaj/Wipro/CG/Surya/Pyrotech/Syska/Nessa/C&S having surge Protection $\geq 10KV$ for fittings & internal Surge Protection for Driver of $\geq 4KV$, LED Chip only OSRAM/CREE/Philips Lumileds/Citizen/ with LM-79,80 CERTIFICATION
32	CEILING FANS	BAJAJ/ORIENT/USHA/CROMPTON GREAVES / ALMONARD/GEC
33	WALL MOUNTING FANS	BAJAJ/ORIENT/USHA/CROMPTON GREAVES / ALMONARD/GEC
34	EXHUAUST FANS	BAJAJ/ORIENT/USHA/CROMPTON GREAVES / ALMONARD/GEC
35	HEAVY DUTY INDUSTRIAL WALL MOUNTING FANS	BAJAJ/ORIENT/USHA/CROMPTON GREAVES / ALMONARD/GEC or its equivalent
36	WATER COOLER	VOLTAS/SHRIRAM USHA/BLUE STAR
37	AIR CONDITIONERS	VOLTAS/CARRIER/BLUESTAR/USHA/ HITACHI/LG/

Operation & Maintenance Contract of Industrial Lighting at cargo handling area, open plots, jetty area, Godowns, Street lighting connecting to port gates including maintenance of 11/0.433KV Substation inside cargo jetty area for a period of two years.

		SAMSUNG/ONIDA
38	REFRIGERATORS	VOLTAS / CARRIER / BLUESTAR / USHA / HITACHI / LG / SAMSUNG / WHIRLPOOL
39	VOLTAGE STABILIZER	VEELINE / CAPRI
40	INVERTERS	SUKAM / MICROTEK
41	D.G. SETS	
	A) ENGINE	CUMMINS/GREAVES/KIRLOSKAR/CATERPILLAR/ASHOK LEYLAND /VOLVO
	B) ALTERNATOR	STAMFORD/CROMPTON GREAVES /JYOTI/ KIRLOSKAR ELECTRIC
42	ELECTRIC MOTOR	ALSTOM/CROMPTON GREAVES /SIEMENS/ KIRLOSKAR/ABB
43	WATER PUMPS	SWASTIK / KSB
44	WATER GEYSER	BAJAJ/USHA / CROMPTON GREAVES / SPHEREHOT / RACOLD
45	LUGS & CABLE GLANDS	DOWELLS / JAINSON / BRACO

Note:

In case of supply of Make of material which is not in the DPA approved Make list, the said material should be supplied as per the latest GETCO approved Make list.

In case of supply of Make of material which is neither available in the DPA approved Make list not in the latest GETCO approved Make list, the said material should be supplied as per the Make decided by EIC for which written intimation will be given to the contractor.

Before procurement of material, the Make of the material should be approved by EIC in writing.

**Signature & Seal
of Contractor**

**-Sd/-
Superintending Engineer (E)
Deendayal Port Authority**

Removing, Shifting & Re-erection the Electrical Substation equipment's from 6th berth S/s to proposed location thereof in side cargo jetty area.

SECTION IX

(To be Executed on Rs. 300/- Non Judicial Stamp Paper)

Integrity Pact

The Integrity Pact duly signed by authorized person(s) with witness are to be submitted by the bidders along with the tender documents.

Bidders are required to sign the integrity pact (as per given below with the tender document), failing which their bid shall be liable for rejection. The "principal" means "Deendayal Port Authority" and "Counterparty" means "Vendor / Supplier/ Contractor".

If a Counterparty commits a violation of its Commitments and Obligations under the Integrity Pact Program during bidding process, their entire Earnest Money Deposit, would be forfeited and in addition, they may be blacklisted from the DPA business in future.

In case of violation of the Integrity Pact by Counterparty after award of the Contract, DPA shall be entitled to terminate the contract. DPA would forfeit the Security Deposits; encase the Bank Guarantee (s) and other payments to Counterparty in such cases.

**Seal & Signature
of Contractor**

**Sd/-
Executive Engineer(E)
Deendayal Port Authority**

INTEGRITY PACT

Between

Deendayal Port Authority (DPA) hereinafter referred to as "**The Principal**"
and

..... (Name of The bidders and consortium
members) hereinafter referred to as "**The Bidder / Contractor**"

Preamble

The Principal intends to award, under laid down organizational procedures, contract(s) / concession(s) for Tender No. The Principal values full compliance with all relevant laws of the land rules, regulations, economic use of resources and of fairness / transparency in its relations with its Bidder(s) and / or Contractor(s).

In order to achieve these goals, the Principal will appoint Independent External Monitors (IEMs), who will monitor the tender process and the execution of the contract for compliance with the principles mentioned above.

Section 1 - Commitments of the Principal

- (1) The Principal commits itself to take all measures necessary to prevent corruption and to observe the following principles:-
 - (a) No employee of the Principal, personally or through family members, will in connection with the tender for, or the execution of a contract, demand, take a promise for or accept, for self or third person, any material or immaterial benefit which the person is not legally entitled to.
 - (b) The Principal will, during the tender process treat all Bidder(s) with equity and reason. The Principal will in particular, before and during the tender process, provide to all Bidder(s) the same information and will not provide to any Bidder(s) confidential / additional information through which the Bidder(s) could obtain an advantage in relation to the tender process or the contract execution.
 - (c) The Principal will exclude from the process all known prejudicial persons.
- (2) If the Principal obtains information on the conduct of any of its employees which is a criminal offence under the IPC / PC Act, or if there be a substantive suspicion in this regard, the Principal will inform the Chief Vigilance Officer and in addition can initiate disciplinary actions.

Section 2 - Commitments of the Bidder(s) / Contractor(s)

- (1) The Bidder(s) / Contractor(s) commits themselves to take all measures necessary to prevent corruption. The Bidder(s) / Contractor(s) commits

themselves to observe the following principles during participation in the tender process and during the contract execution.

- a. The Bidder(s) / Contractor(s) will not, directly or through any other person or firm, offer, promise or give to any of the Principal's employees involved in tender process or the execution of the contract or to any third person any material or other benefit, which he / she is not legally entitled to, in order to obtain in exchange of advantage of any kind whatsoever during the tender process or during the execution of the contract.
 - b. The Bidder(s) / Contractor(s) will not enter with other Bidders into any undisclosed agreement or understanding, whether formal or informal. This applies in particular to prices, specifications, certifications, subsidiary contracts, submission or non-submission of bids, or any other actions to restrict competitiveness or to introduce cartelization in the bidding process.
 - c. The Bidder(s) / Contractor(s) will not commit any offence, under the relevant Prevention of Corruption Act / Indian Penal Code / PC Act; further the Bidder(s) / Contractor(s) will not use improperly, for purposes of competition, or personal gain, or pass on to others, any information or document provided by the Principal, as part of the business relationship, regarding plans, technical proposals and business details, including information contained or transmitted electronically.
 - d. The Bidder(s) / Contractor(s) of foreign origin shall disclose the name and address of the Agents / Representatives in India, if any. Similarly, the Bidder(s) / Contractor(s) of Indian Nationality shall furnish the name and address of the foreign principals, if any. Further details as mentioned in the "Guidelines on Indian Agents of Foreign Suppliers" shall be disclosed by the Bidder(s) / Contractor(s). Further, as mentioned in the Guidelines all the payments made to Indian agent / representative have to be in Indian Rupees only. Copy of the "Guidelines on Indian Agents of Foreign Suppliers" is placed at (page Nos. 7-20)
 - e. The Bidder(s) / Contractor(s) will, when presenting their bid, disclose any and all payments made, is committed to or intends to make to agents, brokers or any other intermediaries, in connection with the award of the contract.
 - f. Bidder(s) / Contractor(s) who have signed the Integrity Pact shall not approach the Courts while representing the matter to IEMs and shall wait for their decision in the matter.
- (2) The Bidder(s) / Contractor(s) will not instigate third persons to commit offences outlined above or be an accessory to such offences.

Section 3 - Disqualification from tender process and exclusion from future contracts.

If the Bidder(s) / Contractor(s), before award or during execution has committed a transgression through a violation of Section-2 above, or in any other form, such as to put their reliability or credibility in question, the Principal is entitled to disqualify the Bidder (s) / Contractor(s), from the tender process, or take action as per the procedure mentioned in the "Guidelines on Banning of business dealings". Copy of the "Guidelines on Banning of business dealings" is placed at (Page No. 7-20).

Section 4 - Compensation for Damages

- (1) If the Principal has disqualified the Bidder(s), from the tender process prior to the award, according to Section 3, the Principal is entitled to demand and recover the damages equivalent to Earnest Money Deposit / Bid Security.
- (2) If the Principal has terminated the contract according to Section 3, or if the Principal is entitled to terminate the contract according to Section 3, the Principal shall be entitled to demand and recover from the Contractor, liquidated damages of the Contract Value or the amount equivalent to Security Deposit / Performance Bank Guarantee, whichever is higher.
- (3) The Bidder(s) agrees and undertakes to pay the said amounts, without protest or demur, subject only to condition that, if the Bidder(s) / Contractor(s) can prove and establish that the termination of the contract, after the contract award has caused no damage or less damage than the amount of the liquidated damages, the Bidder/Contractor shall compensate the principal, only to the extent of the damage in the amount proved.

Section 5 - Previous transgression

- (1) The Bidder declares that, no previous transgressions occurred in the last three years with any other company in any country confirming to the anti-corruption approach or with any other Public Sector Enterprises in India, that could justify his exclusion from the tender process.
- (2) If the Bidder makes incorrect statement on this subject, he can be disqualified from the tender process or action can be taken as per the procedure mentioned in "Guidelines on Banning of Business dealing".

Section 6 - Equal treatment of all Bidders / Contractors

- (1) In case of a Joint Venture, all the partners of the Joint Venture will enter into agreement with identical conditions as this on which all Bidders.
- (2) There is no provision of sub-contract in the tender, any violation of the same, Contractor shall be held solely responsible for the same.

Section 7 - Criminal charges against violating Bidders / Contractors

If the principal obtains knowledge of conduct of a Bidder or Contractor or of an employee, or a representative, or an associate of a Bidder or Contractor, which constitutes corruption, or if the Principal has substantive suspicion, in this regard, the Principal will inform the same to the Chief Vigilance Officer (CVO) and the CVO will take further necessary action as deemed fit in accordance with the CVC Manual.

Section 8 - External Independent Monitor

- (1) The Principal appoints competent and credible Independent External Monitor for this Pact after approval by Central Vigilance Commission. The task of the Monitor is to review independently and objectively, whether and to what extent the parties comply with the obligations under this agreement.
- (2) The Monitor is not subject to instructions by the representative of the parties and performs his / her functions neutrally and independently. The Monitor would have access to all Contract documents, whenever required. It will be obligatory for him / her to treat the information and documents of the Bidders / Contractors as confidential. He / she reports to the Chairperson of the Board of the Principal.
- (3) The Bidder(s) / Contractor(s) accepts that the Monitor has the right to access without restriction to all Project documentation of the Principal including that provided by the Contractor. The Bidder / Contractor will also grant the Monitor, upon his / her request and demonstration of a valid interest, unrestricted and unconditional access to the project documentation. The Monitor is under contractual obligation, to treat the information and documents of the Bidder / Contractor with confidentiality.
- (4) The Monitor is under contractual obligation to treat the information and documents of the Bidder(s) / Contractor(s) with confidentiality. The Monitor has also signed declaration on "Non-Disclosure of Confidential Information" and of "Absence of Conflict of Interest". In case of any conflict of interest arising at a later date, the IEM shall inform Chairman, DPA and recues himself / herself from that case
- (5) The Principal will provide to the Monitor sufficient information about all meetings among the parties related to the Project provided such meetings could have an impact on the contractual relations between the Principal and the Bidder / Contractor. The parties offer to the Monitor the option to participate in such meetings.
- (6) As soon as the Monitor notices, or believes to notice, a violation of this agreement, he / she will so inform the Management of the Principal and request

the management to discontinue, or take corrective action. The Monitor can in this regard submit non-binding recommendations. Beyond this, the Monitor has no right to demand from the parties that they act in a specific manner, refrain from action or tolerate action.

- (7) The Monitor will submit a written report to the Chairperson of the Board of the Principal, within 8 to 10 weeks from the date of reference or intimation to him by the Principal and, should the occasion arise, submit proposals for correcting problematic situations.
- (8) If the Monitor has reported to the Chairperson of the Board of the Principal, a substantiated suspicion of an offence under relevant IPC / PC Act and the Chairperson of the Board of the Principal has not, within reasonable time taken visible action to proceed against such offence or reported it to the Chief Vigilance Officer, the Monitor may also transmit this information directly to the Central Vigilance Commissioner, Government of India.
- (9) The word "**Monitor**" would include both singular and plural.

Section 9 - Pact Duration

- 9.1 This Pact shall be operative from the date of signing of IP by both the parties till the final completion of contract of successful bidder and for all other bidders six months after the contract has been awarded. Issues like warranty, guarantee, etc. should be outside the purview of IEMs.
- 9.2 If any claim is made / lodged during this time, the same shall be binding and continue to be valid despite the lapse of this pact, as specified above unless it is discharged / determined by the Chairperson, DPA.

Section 10 - Other Provisions

- (1) This agreement is subject to Indian Law. Place of performance and jurisdiction is the Registered Office of the Principal, i.e. Gandhidham, Gujarat.
- (2) Changes and supplements as well as termination notices need to be made in writing. Side agreements have not been made.
- (3) If the Bidder / Contractor is a partnership or a consortium, this agreement must be signed by all partners or consortium members.
- (4) Should one or several provisions of this agreement, turn out to be invalid, the remainder of this agreement remains valid. In this case, the parties will strive to come to an agreement to their original intentions.
- (5) Issues like Warranty / Guarantee etc. shall be outside the purview of IEMs.


(6) In the event of any contradiction between the Integrity Pact and its Annexure, the Clause in the Integrity Pact will prevail.


अभिषारी अभियंता (विद्युत)
(For & on behalf of the Bidder/Contractor)
Executive Engineer (Elect.)
Deendayal Port Authority

Place : Gandhidham

Date : ___/___/20

Signature of Witness
(Sign, Name & Address)


Amit Rautiy
Room No. 111, Nirman
Building, New Landla

(For & on behalf of the Bidder/Contractor)
(Office Seal)

Signature of Witness
(Sign, Name & Address)

Note: The bidder has to executed Integrity pact agreement with Deendayal Port Authority (as per Bid Response sheet no. 10 and Shri Amiya Kumar Mohapatra, IFoS (Retd.) and Shri Dr. Gopal Dhawan, EX-CMD, have been appointed by DPA as Independent External Monitors and whose address are as under:-

(1) Shri Amiya Kumar Mohapatra, IFoS (Ret.)
Qrs. No. 5/9, Unit-9, Bhoi Nagar,
Bhubaneswar- 751 022.
Mobile No. 9437002530
Email: amiyaifs@gmail.com

(2) Shri Dr. Gopal Dhawan, Ex CMD, MECL
House No. 120, Jai Shakti Vihar
(NHPC Society) P4, Builder Area,
Greate Noida Gautam Budh nagar,
Utter Pradesh-201 315.
Mobile No. 8007771467
Email: gdhawangeologist@gmail.com